

初野浄水場 流量水質報告書

平成28年4月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	31,840	2.13	7.49	—	18,940	16,360	1.56	7.50	8.50	0.00	0.00	
2	31,980	2.12	7.49	—	18,860	15,860	1.53	7.49	8.10	0.00	0.00	
3	31,220	2.16	7.49	—	19,220	15,070	1.55	7.52	8.40	0.00	0.00	
4	30,590	2.32	7.49	—	18,230	14,810	1.61	7.47	9.00	0.00	0.00	
5	31,150	2.50	7.45	—	18,600	15,600	1.64	7.49	8.90	0.00	0.00	
6	31,310	2.37	7.49	—	18,020	15,720	1.81	7.47	8.90	0.00	0.00	
7	31,080	2.24	7.47	—	17,790	15,570	1.61	7.46	9.20	2.40	0.00	
8	32,350	4.99	7.43	—	18,980	16,210	2.76	7.46	9.40	0.00	0.00	
9	30,190	3.08	7.41	—	17,270	15,140	2.11	7.45	9.50	0.00	0.00	
10	31,870	2.79	7.41	—	18,110	15,580	1.76	7.45	9.90	0.00	0.00	
11	30,520	2.90	7.42	—	17,610	14,880	1.98	7.44	9.60	0.00	0.00	
12	31,020	3.05	7.43	—	18,040	15,640	2.05	7.46	9.60	0.00	0.00	
13	31,520	3.28	7.43	—	18,310	15,860	2.11	7.43	9.60	0.00	0.00	
14	31,240	3.25	7.42	—	17,570	15,760	2.13	7.41	10.00	2.40	0.00	
15	31,500	3.99	7.40	—	18,170	15,810	3.64	7.39	10.00	0.00	0.00	
16	31,350	3.87	7.39	—	18,090	15,890	2.60	7.43	10.20	0.00	0.00	
17	31,980	3.88	7.40	—	18,610	15,490	2.50	7.39	9.90	0.00	0.00	
18	31,410	3.83	7.39	—	18,670	15,370	2.41	7.42	10.50	0.00	0.00	
19	30,780	3.70	7.37	—	17,330	15,570	2.40	7.40	10.60	0.00	0.00	
20	32,510	3.78	7.36	—	18,350	16,320	2.31	7.40	10.60	0.00	0.00	
21	30,380	3.65	7.38	—	17,010	15,120	2.34	7.39	10.60	2.40	0.00	
22	31,270	3.63	7.37	—	17,480	15,630	2.36	7.36	10.80	0.00	0.00	
23	32,140	3.85	7.35	—	18,950	15,800	2.36	7.37	10.80	0.00	0.00	
24	32,010	3.60	7.36	—	19,230	15,310	2.43	7.37	11.00	0.00	0.00	
25	31,770	3.58	7.36	—	18,480	15,160	2.32	7.37	11.30	0.00	0.00	
26	32,620	3.48	7.34	—	18,470	15,760	2.28	7.38	11.50	0.00	0.00	
27	31,120	3.45	7.32	—	17,260	15,170	2.21	7.36	11.60	2.40	0.00	
28	32,120	3.93	7.42	—	17,930	15,610	2.42	7.38	11.90	0.00	0.00	
29	32,340	4.97	7.38	—	18,640	15,190	3.30	7.39	12.30	0.00	0.00	
30	32,640	4.40	7.43	—	19,050	15,340	2.74	7.42	12.70	0.00	0.00	
合計	945,820			—	547,270	466,600				9.60	0.00	
最大	32,640	4.99	7.49	—	19,230	16,360	3.64	7.52	12.70	2.40	0.00	
最少	30,190	2.12	7.32	—	17,010	14,810	1.53	7.36	8.10	0.00	0.00	
平均	31,527	3.36	7.41	—	18,242	15,553	2.23	7.42	10.16	0.32	0.00	

初野浄水場 流量水質報告書

平成28年5月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	32,010	4.45	7.38	—	19,230	15,010	2.73	7.37	12.40	0.00	0.00	
2	31,840	4.97	7.23	—	19,110	14,670	3.09	7.18	13.10	0.00	0.00	
3	29,940	4.77	7.39	—	17,480	13,800	3.11	7.38	12.00	0.00	0.00	
4	32,230	4.71	7.41	—	19,400	14,910	3.09	7.35	12.20	0.00	0.00	
5	32,310	4.71	7.43	—	19,710	14,900	3.09	7.40	12.60	0.00	0.00	
6	32,070	4.64	7.47	—	19,000	15,220	3.12	7.48	13.10	2.40	0.00	
7	31,980	4.91	7.37	—	18,930	15,160	3.24	7.41	12.80	0.00	0.00	
8	32,130	5.18	7.63	—	19,440	15,150	3.28	7.51	13.40	0.00	0.00	
9	31,570	4.98	7.52	—	18,350	14,820	3.36	7.50	13.60	0.00	0.00	
10	31,160	4.90	7.43	—	17,950	15,470	3.18	7.40	13.20	0.00	0.00	
11	31,510	4.99	7.47	—	18,170	15,540	3.26	7.37	13.10	0.00	0.00	
12	30,930	5.14	7.66	—	17,970	15,230	3.21	7.44	13.30	2.40	0.00	
13	31,720	5.19	7.49	—	17,650	15,910	3.39	7.48	14.00	0.00	0.00	
14	30,740	5.23	7.49	—	17,130	15,350	3.39	7.42	13.70	0.00	0.00	
15	31,130	5.20	7.55	—	17,990	15,020	3.45	7.42	13.00	0.00	0.00	
16	31,190	5.17	7.54	—	17,600	15,000	3.40	7.45	13.90	0.00	0.00	
17	31,070	5.24	7.52	—	17,570	15,340	3.40	7.41	14.20	0.00	0.00	
18	32,180	3.41	7.42	—	18,850	15,840	2.28	7.41	14.10	0.00	0.00	
19	30,470	3.55	7.40	—	17,350	15,120	2.44	7.37	14.20	0.00	0.00	
20	31,130	3.69	7.37	—	17,430	15,470	2.44	7.35	14.40	0.00	0.00	
21	31,300	3.82	7.35	—	17,980	15,480	2.61	7.33	14.30	0.00	0.00	
22	31,180	4.04	7.32	—	18,070	15,080	2.68	7.32	14.50	0.00	0.00	
23	31,210	3.96	7.29	—	18,580	14,940	2.75	7.31	14.70	0.00	0.00	
24	31,530	4.02	7.24	—	17,520	15,920	2.76	7.27	15.20	0.00	0.00	
25	30,600	4.32	7.30	—	17,500	15,220	3.14	7.28	15.50	0.00	0.00	
26	31,110	4.32	7.28	—	17,880	15,350	2.99	7.26	15.90	2.40	0.00	
27	30,680	4.33	7.26	—	17,010	15,190	2.98	7.23	15.90	0.00	0.00	
28	31,610	4.28	7.24	—	17,970	15,480	2.96	7.24	16.00	0.00	0.00	
29	30,960	4.21	7.23	—	17,760	14,920	3.02	7.25	16.00	0.00	0.00	
30	31,080	4.22	7.18	—	17,790	14,960	3.74	7.21	16.10	0.00	0.00	
31	31,370	2.45	7.12	—	17,770	15,690	1.78	7.19	15.70	0.00	0.00	
合計	971,940			—	562,140	471,160				7.20	0.00	
最大	32,310	5.24	7.66	—	19,710	15,920	3.74	7.51	16.10	2.40	0.00	
最少	29,940	2.45	7.12	—	17,010	13,800	1.78	7.18	12.00	0.00	0.00	
平均	31,353	4.48	7.39	—	18,134	15,199	3.01	7.35	14.07	0.23	0.00	

初野浄水場 流量水質報告書

平成28年6月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	30,780	2.61	7.10	—	17,240	15,330	1.74	7.19	15.40	0.00	0.00	
2	31,010	3.01	7.11	—	17,130	15,370	1.93	7.21	15.70	2.40	0.00	
3	31,200	3.18	7.13	—	17,190	15,810	2.18	7.21	15.40	0.00	0.00	
4	31,160	3.25	7.14	—	17,480	15,790	2.18	7.21	15.20	0.00	0.00	
5	30,120	3.25	7.12	—	17,320	14,960	2.22	7.20	15.40	0.00	0.00	
6	30,510	3.22	7.09	—	17,930	14,940	2.13	7.16	15.20	0.00	0.00	
7	31,240	3.16	7.14	—	18,030	15,950	2.13	7.19	15.20	0.00	0.00	
8	30,940	3.20	7.09	—	18,120	15,730	2.08	7.16	15.40	0.00	0.00	
9	30,570	3.21	7.10	—	17,530	15,680	2.10	7.17	15.50	2.40	0.00	
10	30,560	3.11	7.12	—	17,460	15,650	2.03	7.17	15.60	0.00	0.00	
11	30,800	3.14	7.11	—	17,260	15,670	2.10	7.19	15.80	0.00	0.00	
12	30,700	3.27	7.07	—	17,220	15,020	2.07	7.15	15.70	0.00	0.00	
13	31,160	3.24	7.09	—	18,110	15,210	2.05	7.15	15.70	0.00	0.00	
14	30,510	3.35	7.06	—	18,150	15,170	2.21	7.14	16.50	0.00	0.00	
15	31,860	3.24	7.01	—	18,930	15,930	1.97	7.11	15.60	0.00	0.00	
16	29,620	3.31	7.06	—	17,430	15,210	1.97	7.12	16.40	2.40	0.00	
17	30,380	3.16	7.05	—	17,330	15,570	1.20	7.13	15.90	0.00	0.00	
18	30,990	3.21	7.05	—	17,630	16,000	1.24	7.19	16.00	0.00	0.00	
19	29,960	3.66	7.06	—	17,300	14,900	1.45	7.18	16.00	0.00	0.00	
20	30,460	3.53	7.07	—	18,440	15,080	1.42	7.15	15.90	0.00	0.00	
21	29,740	1.77	7.06	—	17,210	15,420	1.34	7.11	15.10	0.00	0.00	
22	31,720	1.84	7.03	—	18,360	16,240	1.35	7.08	14.70	0.00	0.00	
23	30,510	1.77	6.99	—	17,520	15,640	1.33	7.10	14.60	2.40	0.00	
24	30,430	1.90	7.01	—	17,960	15,840	1.37	7.10	14.60	0.00	0.00	
25	30,280	1.77	7.01	—	18,110	15,700	1.37	7.07	14.60	0.00	0.00	
26	30,390	2.04	7.05	—	18,080	15,280	1.47	7.17	14.70	0.00	0.00	
27	30,350	2.08	7.07	—	17,930	15,230	1.47	7.19	14.80	0.00	0.00	
28	30,130	2.01	7.04	—	17,480	15,830	1.44	7.12	14.50	0.00	0.00	
29	30,700	1.96	7.02	—	18,420	15,870	1.31	7.13	14.70	0.00	0.00	
30	29,990	1.98	7.04	—	17,230	15,670	1.23	7.06	14.80	2.40	0.00	
合計	918,770			—	531,530	465,690				12.00	0.00	
最大	31,860	3.66	7.14	—	18,930	16,240	2.22	7.21	16.50	2.40	0.00	
最少	29,620	1.77	6.99	—	17,130	14,900	1.20	7.06	14.50	0.00	0.00	
平均	30,626	2.78	7.07	—	17,718	15,523	1.74	7.15	15.35	0.40	0.00	

初野浄水場 流量水質報告書

平成28年7月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	30,410	1.91	7.02	—	17,850	15,920	1.17	7.10	15.00	0.00	0.00	
2	30,200	1.90	7.04	—	16,540	15,930	1.11	7.08	15.10	0.00	0.00	
3	30,200	1.87	7.04	—	16,470	15,200	1.06	7.07	14.90	0.00	0.00	
4	30,110	1.83	7.04	—	17,040	15,160	1.03	7.08	14.90	0.00	0.00	
5	30,210	1.88	6.97	—	17,370	15,850	0.94	7.11	14.70	0.00	0.00	
6	30,360	2.01	7.08	—	18,210	15,640	1.22	7.13	16.80	0.00	0.00	
7	30,030	1.99	7.15	—	17,640	15,530	0.74	7.18	17.40	2.40	0.00	
8	30,210	1.87	7.06	—	17,520	15,610	0.67	7.13	16.80	0.00	0.00	
9	30,130	1.89	7.01	—	17,390	15,640	2.22	7.01	15.40	0.00	0.00	
10	30,310	1.88	7.02	—	18,660	15,160	0.63	7.10	15.10	0.00	0.00	
11	30,510	1.93	7.02	—	17,970	15,330	0.61	7.12	15.10	0.00	0.00	
12	30,620	1.93	6.99	—	17,520	16,070	0.59	7.07	15.20	0.00	0.00	
13	30,350	1.93	7.01	—	16,720	15,930	0.55	7.10	15.10	0.00	0.00	
14	30,150	1.94	6.99	—	16,560	15,740	0.44	7.07	15.10	2.40	0.00	
15	30,640	1.99	6.98	—	17,310	16,060	0.41	7.05	15.00	0.00	0.00	
16	30,310	2.03	6.97	—	18,130	15,640	0.58	7.04	15.10	0.00	0.00	
17	31,070	2.11	6.99	—	18,490	15,380	0.53	7.06	15.10	0.00	0.00	
18	29,840	2.12	7.00	—	18,220	14,770	0.50	7.05	15.20	0.00	0.00	
19	30,230	2.02	6.98	—	17,200	15,240	0.53	7.04	15.20	0.00	0.00	
20	31,140	2.00	6.98	—	17,540	16,510	0.57	7.08	15.20	0.00	0.00	
21	29,720	2.01	6.95	—	16,970	15,430	0.60	7.00	15.00	0.00	0.00	
22	30,390	2.01	6.94	—	17,750	15,760	0.59	7.05	15.20	0.00	0.00	
23	30,780	2.02	6.95	—	17,720	16,020	0.53	7.07	15.20	0.00	0.00	
24	30,020	2.07	6.95	—	17,910	14,930	0.67	7.07	15.20	0.00	0.00	
25	30,260	2.07	6.95	—	18,050	15,350	0.70	7.10	15.30	0.00	0.00	
26	30,760	2.92	6.97	—	17,530	16,120	0.74	7.03	15.30	0.00	0.00	
27	29,900	2.05	6.95	—	17,360	15,720	0.71	7.00	15.20	0.00	0.00	
28	29,930	2.05	6.96	—	16,810	15,740	0.63	7.01	15.30	0.00	0.00	
29	30,460	1.94	6.93	—	17,090	16,110	0.62	7.01	15.40	0.00	0.00	
30	32,160	1.92	6.94	—	16,850	15,630	0.64	7.02	15.30	0.00	0.00	
31	33,690	1.95	6.91	—	20,930	15,350	0.62	7.04	15.30	0.00	0.00	
合計	945,100			—	545,320	484,470				4.80	0.00	
最大	33,690	2.92	7.15	—	20,930	16,510	2.22	7.18	17.40	2.40	0.00	
最少	29,720	1.83	6.91	—	16,470	14,770	0.41	7.00	14.70	0.00	0.00	
平均	30,487	2.00	6.99	—	17,591	15,628	0.75	7.07	15.33	0.15	0.00	

初野浄水場 流量水質報告書

平成28年8月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	32,560	1.93	6.89	—	20,070	14,730	0.69	7.00	15.30	0.00	0.00	
2	32,880	2.02	6.88	—	20,730	15,150	0.60	6.95	15.40	0.00	0.00	
3	31,230	1.95	6.89	—	18,310	15,320	0.48	6.98	15.30	0.00	0.00	
4	31,210	1.91	6.89	—	18,040	15,180	0.40	6.98	15.30	2.40	0.00	
5	30,710	2.16	6.99	—	17,450	14,990	0.56	7.13	19.20	0.00	0.00	
6	30,670	1.18	6.99	—	17,370	14,800	0.80	7.14	20.00	0.00	0.00	
7	31,150	1.30	6.96	—	17,900	14,730	0.82	7.10	20.10	0.00	0.00	
8	30,740	1.33	6.97	—	18,020	14,820	0.84	7.13	20.20	0.00	0.00	
9	31,050	5.12	6.95	—	18,230	15,740	6.22	7.07	20.30	0.00	0.00	
10	30,460	2.79	6.90	—	17,550	15,410	1.82	7.09	20.40	2.40	0.00	
11	30,930	2.71	6.91	—	17,770	15,710	1.70	7.07	20.10	0.00	0.00	
12	30,880	2.57	6.95	—	18,540	15,410	1.60	7.06	20.10	0.00	0.00	
13	30,740	1.76	6.94	—	18,450	15,120	1.20	7.08	20.10	0.00	0.00	
14	30,970	1.76	6.94	—	18,720	14,700	1.17	7.06	20.00	0.00	0.00	
15	31,040	1.77	6.92	—	18,670	14,620	1.17	7.06	20.10	0.00	0.00	
16	30,530	1.76	6.90	—	18,500	14,650	1.16	7.02	20.20	0.00	0.00	
17	30,800	1.75	6.84	—	19,050	14,780	1.07	7.01	18.90	0.00	0.00	
18	31,000	5.93	6.86	—	18,970	15,520	3.03	6.96	18.90	2.40	0.00	
19	31,030	8.40	6.85	—	19,090	15,750	5.48	6.93	19.00	0.00	0.00	
20	30,670	11.57	6.79	—	18,640	15,320	6.35	6.97	19.00	0.00	0.00	
21	30,810	12.52	6.82	—	19,000	14,930	8.60	6.92	18.90	0.00	0.00	
22	30,950	13.53	6.84	—	18,470	14,940	9.45	6.92	19.10	0.00	0.00	
23	30,930	15.44	6.86	—	18,680	15,590	13.58	6.92	19.40	0.00	0.00	
24	30,880	24.13	6.82	—	18,630	15,480	17.25	6.93	19.80	0.00	0.00	
25	30,690	20.16	6.81	—	18,590	15,470	19.78	6.93	19.60	2.40	0.00	
26	31,510	21.06	6.86	—	18,150	15,960	19.38	6.93	19.60	194.40	0.00	
27	30,470	20.21	6.79	—	17,410	15,260	8.01	6.67	19.60	388.80	0.00	
28	30,760	19.17	6.81	—	19,280	14,680	8.31	6.67	19.30	388.80	0.00	
29	30,580	19.47	6.68	—	18,900	14,720	7.07	6.66	19.30	388.80	0.00	
30	30,890	17.80	6.77	—	18,830	15,540	6.71	6.67	19.20	388.80	0.00	
31	29,620	18.64	6.85	—	18,320	14,820	6.18	6.73	19.20	388.80	0.00	
合計	959,340			—	574,330	469,840				2,148.00	0.00	
最大	32,880	24.13	6.99	—	20,730	15,960	19.78	7.14	20.40	388.80	0.00	
最少	29,620	1.18	6.68	—	17,370	14,620	0.40	6.66	15.30	0.00	0.00	
平均	30,946	8.51	6.87	—	18,527	15,156	5.21	6.96	19.06	69.29	0.00	

初野浄水場 流量水質報告書

平成28年9月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	32,050	25.94	6.90	—	18,490	16,310	6.75	6.71	18.80	388.80	0.00	
2	31,060	24.47	6.89	—	18,110	15,630	8.77	6.72	18.60	388.80	0.00	
3	30,800	22.30	6.87	—	17,960	15,450	7.17	6.70	18.70	388.80	0.00	
4	31,020	21.39	6.89	—	18,720	14,970	8.19	6.70	18.60	388.80	0.00	
5	31,170	21.10	6.91	—	18,920	14,890	6.43	6.70	18.70	388.80	0.00	
6	30,830	19.44	6.88	—	17,850	15,720	6.06	6.71	18.90	388.80	0.00	
7	30,610	16.95	6.84	—	17,270	15,580	5.86	6.68	19.00	388.80	0.00	
8	30,960	15.22	6.90	—	18,600	15,730	5.30	6.69	18.80	388.80	0.00	
9	31,000	14.88	6.90	—	19,220	15,660	5.75	6.76	19.00	388.80	0.00	
10	30,730	14.16	6.93	—	17,440	15,610	4.95	6.76	19.10	388.80	0.00	
11	31,170	12.59	6.92	—	18,760	14,960	5.62	6.74	18.90	388.80	0.00	
12	30,640	12.87	6.81	—	18,900	14,700	5.49	6.71	18.70	388.80	0.00	
13	31,060	12.19	6.80	—	18,790	15,610	4.35	6.72	18.50	388.80	0.00	
14	31,000	11.97	6.78	—	18,620	15,590	5.04	6.69	18.60	388.80	0.00	
15	30,910	10.87	6.82	—	18,170	15,660	4.46	6.67	18.50	388.80	0.00	
16	30,820	10.82	6.85	—	17,700	15,510	4.23	6.67	18.50	388.80	0.00	
17	30,940	9.54	6.89	—	18,430	15,430	3.87	6.71	18.50	388.80	0.00	
18	30,940	8.78	6.87	—	18,660	14,830	4.53	6.75	18.40	388.80	0.00	
19	31,030	8.60	6.80	—	19,480	14,770	4.55	6.70	18.30	388.80	0.00	
20	31,370	8.43	6.78	—	19,620	15,060	4.38	6.73	18.10	388.80	0.00	
21	30,440	9.43	6.74	—	18,570	14,940	4.55	6.70	18.00	388.80	0.00	
22	30,900	10.58	6.83	—	18,270	15,370	4.80	6.73	17.70	388.80	0.00	
23	31,300	10.95	6.87	—	18,780	15,490	4.40	6.71	17.60	388.80	0.00	
24	30,700	11.25	6.89	—	18,490	15,340	3.83	6.75	17.50	388.80	0.00	
25	31,000	10.90	6.93	—	18,750	14,810	4.52	6.77	17.40	388.80	0.00	
26	31,220	10.33	6.95	—	18,670	15,000	4.22	6.78	17.50	388.80	0.00	
27	30,940	10.31	6.93	—	18,580	15,600	3.12	6.76	17.50	226.80	0.00	
28	31,190	9.69	6.98	—	18,650	15,750	8.70	7.07	17.50	0.00	0.00	
29	30,740	9.54	6.95	—	18,240	15,590	8.34	7.05	17.50	0.00	0.00	
30	31,130	8.80	6.98	—	18,510	15,520	7.38	7.10	17.50	0.00	0.00	
31												
合計	929,670			—	555,220	461,080				10,335.60	0.00	
最大	32,050	25.94	6.98	—	19,620	16,310	8.77	7.10	19.10	388.80	0.00	
最少	30,440	8.43	6.74	—	17,270	14,700	3.12	6.67	17.40	0.00	0.00	
平均	30,989	13.48	6.88	—	18,507	15,369	5.52	6.75	18.30	344.52	0.00	

初野浄水場 流量水質報告書

平成28年10月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	31,030	8.82	7.00	—	18,160	15,360	8.05	7.07	17.20	0.00	0.00	
2	31,170	8.78	6.98	—	18,430	14,830	7.69	7.08	17.30	0.00	0.00	
3	30,680	9.07	6.99	—	18,080	14,640	7.75	7.08	17.30	0.00	0.00	
4	31,070	8.81	6.97	—	18,210	15,630	7.40	7.10	17.50	0.00	0.00	
5	31,300	8.41	6.99	—	18,690	15,600	6.96	7.11	17.40	0.00	0.00	
6	30,780	8.46	6.95	—	18,100	15,260	6.61	7.07	17.40	2.40	0.00	
7	30,890	8.25	6.94	—	17,790	15,420	6.46	7.13	17.50	0.00	0.00	
8	31,170	7.96	6.97	—	18,030	15,380	6.35	7.06	17.20	0.00	0.00	
9	30,910	7.85	6.95	—	19,070	14,700	6.29	7.03	17.20	0.00	0.00	
10	30,950	7.76	6.98	—	19,390	14,720	6.01	7.11	17.10	0.00	0.00	
11	30,910	7.79	6.93	—	18,790	14,910	6.05	7.07	16.80	0.00	0.00	
12	31,160	6.55	6.90	—	18,390	15,260	5.12	7.02	15.40	0.00	0.00	
13	31,290	6.70	6.90	—	18,550	15,430	4.95	7.01	15.30	2.40	0.00	
14	30,960	6.48	6.90	—	17,920	15,270	4.96	7.04	15.20	0.00	0.00	
15	31,570	6.50	6.93	—	18,370	15,590	5.01	7.02	15.10	0.00	0.00	
16	30,640	6.31	6.96	—	18,390	14,760	4.85	7.03	15.10	0.00	0.00	
17	31,750	6.52	6.95	—	19,090	15,100	4.79	7.04	15.20	0.00	0.00	
18	30,500	6.41	6.95	—	18,590	15,020	4.57	7.08	15.30	0.00	0.00	
19	30,910	5.69	6.92	—	17,880	15,510	4.58	7.01	15.20	0.00	0.00	
20	31,160	5.32	6.97	—	18,090	15,570	4.54	7.04	15.20	2.55	0.00	
21	31,110	5.14	6.95	—	18,370	15,730	3.95	7.15	15.30	0.00	0.00	
22	30,900	5.88	6.94	—	17,640	15,340	4.11	7.09	15.00	0.00	0.00	
23	31,240	5.22	6.91	—	17,720	15,000	4.25	7.02	15.00	0.00	0.00	
24	30,970	5.13	6.97	—	18,100	14,810	4.01	7.08	14.80	0.00	0.00	
25	31,110	2.94	6.96	—	18,540	15,570	2.68	7.08	14.70	0.00	0.00	
26	31,000	2.86	6.92	—	17,880	15,530	2.59	7.04	14.90	0.00	0.00	
27	31,080	2.59	6.89	—	18,100	15,670	2.43	7.04	14.80	0.00	0.00	
28	30,930	2.45	6.89	—	17,280	15,490	2.39	7.05	14.70	0.00	0.00	
29	30,890	2.65	6.83	—	18,410	15,370	2.53	7.02	14.50	0.00	0.00	
30	30,860	2.73	6.92	—	18,490	14,820	2.55	7.07	14.20	0.00	0.00	
31	31,470	2.71	7.01	—	19,020	15,050	2.58	7.09	14.10	0.00	0.00	
合計	962,360			—	567,560	472,340				7.35	0.00	
最大	31,750	9.07	7.01	—	19,390	15,730	8.05	7.15	17.50	2.55	0.00	
最少	30,500	2.45	6.83	—	17,280	14,640	2.39	7.01	14.10	0.00	0.00	
平均	31,044	6.09	6.94	—	18,308	15,237	4.94	7.06	15.77	0.24	0.00	

初野浄水場 流量水質報告書

平成28年11月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	30,930	2.64	7.00	—	18,200	15,350	2.55	7.08	14.00	0.00	0.00	
2	31,130	2.70	6.93	—	18,670	15,400	2.57	7.09	13.80	2.40	0.00	
3	31,040	2.62	6.99	—	18,140	15,540	2.50	7.09	13.80	0.00	0.00	
4	31,490	2.78	6.99	—	18,650	15,760	2.64	7.09	13.60	0.00	0.00	
5	31,000	2.73	7.01	—	18,320	15,560	2.67	7.13	13.60	0.00	0.00	
6	30,830	2.82	6.97	—	18,600	14,870	2.71	7.11	13.60	0.00	0.00	
7	30,960	2.77	6.97	—	18,710	14,970	2.70	7.11	13.20	0.00	0.00	
8	31,130	2.80	6.99	—	19,010	15,700	2.76	7.10	13.10	0.00	0.00	
9	31,030	2.83	6.93	—	18,610	15,640	2.78	7.10	13.10	0.00	0.00	
10	31,410	2.73	6.99	—	18,340	15,810	2.78	7.16	12.80	2.40	0.00	
11	31,070	2.85	7.01	—	18,420	15,520	2.71	7.15	12.40	0.00	0.00	
12	30,860	3.01	7.03	—	17,770	15,260	2.87	7.14	12.50	0.00	0.00	
13	31,520	2.87	7.07	—	17,960	15,520	2.85	7.15	12.50	0.00	0.00	
14	31,260	2.78	7.05	—	18,120	14,980	2.70	7.13	12.50	0.00	0.00	
15	31,190	2.71	7.03	—	18,970	15,610	2.67	7.10	12.50	0.00	0.00	
16	31,200	2.62	7.00	—	18,550	15,560	2.54	7.14	12.40	0.00	0.00	
17	31,020	2.53	7.05	—	18,380	15,610	2.50	7.14	12.20	2.40	0.00	
18	31,230	2.61	7.01	—	18,020	15,630	2.46	7.13	12.00	0.00	0.00	
19	31,270	2.72	7.02	—	18,720	15,720	2.67	7.11	11.90	0.00	0.00	
20	30,930	2.68	6.98	—	18,990	15,030	2.59	7.09	12.00	0.00	0.00	
21	31,060	2.58	6.98	—	19,030	15,100	2.53	7.08	11.90	0.00	0.00	
22	31,140	2.66	7.00	—	18,380	15,700	2.64	7.10	11.90	0.00	0.00	
23	31,590	2.62	7.00	—	19,180	15,780	2.46	7.10	11.80	0.00	0.00	
24	31,360	2.54	7.02	—	19,390	15,650	2.41	7.13	11.50	0.00	0.00	
25	31,430	2.53	7.04	—	18,660	15,700	2.42	7.15	11.20	2.40	0.00	
26	32,950	2.58	7.00	—	19,480	15,730	2.39	7.11	11.10	0.00	0.00	
27	31,610	2.63	6.95	—	19,630	15,290	2.34	7.09	11.10	0.00	0.00	
28	30,830	2.52	6.94	—	19,160	15,070	2.26	7.07	11.10	0.00	0.00	
29	30,530	2.48	6.99	—	17,940	15,420	2.24	7.11	10.80	0.00	0.00	
30	31,280	2.45	7.05	—	18,830	15,800	2.28	7.16	10.60	0.00	0.00	
31												
合計	936,280			—	558,830	464,280				9.60	0.00	
最大	32,950	3.01	7.07		19,630	15,810	2.87	7.16	14.00	2.40	0.00	
最少	30,530	2.45	6.93		17,770	14,870	2.24	7.07	10.60	0.00	0.00	
平均	31,209	2.68	7.00		18,628	15,476	2.57	7.11	12.35	0.32	0.00	

初野浄水場 流量水質報告書

平成28年12月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	31,810	2.44	7.07	—	18,790	16,140	2.29	7.15	10.60	0.00	0.00	
2	32,540	2.40	7.07	—	19,430	16,520	2.15	7.16	10.50	0.00	0.00	
3	29,670	2.52	7.08	—	17,680	15,010	2.26	7.15	10.50	0.00	0.00	
4	31,490	2.44	7.07	—	18,790	15,500	2.30	7.17	10.40	0.00	0.00	
5	31,240	2.44	7.04	—	19,290	15,300	2.20	7.13	10.40	0.00	0.00	
6	30,670	2.42	7.03	—	17,730	15,640	2.20	7.14	10.40	0.00	0.00	
7	31,270	2.72	7.00	—	18,710	15,970	2.63	7.20	10.10	0.00	0.00	
8	30,990	2.61	7.02	—	17,860	15,840	2.52	7.16	9.90	0.00	0.00	
9	31,530	2.54	6.99	—	18,870	16,010	2.41	7.17	9.70	0.00	0.00	
10	31,600	2.46	6.99	—	18,810	15,800	2.34	7.16	9.70	0.00	0.00	
11	31,400	2.46	6.94	—	19,330	15,240	2.18	7.15	9.40	0.00	0.00	
12	31,350	2.40	7.01	—	18,940	15,250	2.15	7.17	9.20	0.00	0.00	
13	31,470	2.46	7.00	—	18,400	15,670	2.13	7.16	9.10	0.00	0.00	
14	31,440	2.36	6.92	—	18,700	15,920	2.10	7.12	8.90	0.00	0.00	
15	31,310	2.31	6.96	—	18,290	15,610	2.02	7.15	8.80	2.40	0.00	
16	31,360	2.23	6.97	—	17,960	15,710	1.96	7.15	8.60	0.00	0.00	
17	31,450	2.10	6.98	—	18,760	15,690	1.93	7.17	8.50	0.00	0.00	
18	31,620	2.19	6.97	—	19,160	15,490	1.94	7.13	8.50	0.00	0.00	
19	31,520	2.14	6.97	—	18,960	15,340	1.94	7.15	8.50	0.00	0.00	
20	31,500	2.10	6.97	—	18,380	15,810	1.92	7.14	8.50	0.00	0.00	
21	32,310	2.07	6.96	—	18,920	16,290	2.07	7.13	8.60	0.00	0.00	
22	30,530	1.56	6.97	—	17,760	15,400	1.60	7.14	8.40	2.40	0.00	
23	31,470	1.44	6.97	—	18,830	15,760	1.43	7.16	8.70	0.00	0.00	
24	31,510	1.57	7.03	—	18,940	15,500	1.47	7.19	8.60	0.00	0.00	
25	31,820	1.59	7.03	—	19,360	15,520	1.59	7.18	8.30	0.00	0.00	
26	31,220	1.66	7.01	—	18,900	15,170	1.60	7.19	8.10	0.00	0.00	
27	31,390	1.59	7.11	—	18,920	15,780	1.55	7.11	8.20	0.00	0.00	
28	31,660	1.62	7.01	—	19,290	15,760	1.58	7.18	8.00	0.00	0.00	
29	31,530	1.59	7.02	—	19,050	15,430	1.57	7.17	7.80	0.00	0.00	
30	31,390	1.57	7.00	—	18,680	15,240	1.55	7.18	7.70	2.40	0.00	
31	31,480	1.63	7.02	—	18,510	15,210	1.58	7.17	7.50	0.00	0.00	
合計	973,540			—	580,000	484,520				7.20	0.00	
最大	32,540	2.72	7.11	—	19,430	16,520	2.63	7.20	10.60	2.40	0.00	
最小	29,670	1.44	6.92	—	17,680	15,010	1.43	7.11	7.50	0.00	0.00	
平均	31,405	2.12	7.01	—	18,710	15,630	1.97	7.16	9.04	0.23	0.00	

初野浄水場 流量水質報告書

平成29年1月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	31,560	1.57	6.99	—	18,410	15,160	1.57	7.17	7.50	0.00	0.00	
2	31,880	1.56	7.00	—	19,690	15,280	1.56	7.16	7.50	0.00	0.00	
3	31,080	1.57	6.99	—	19,570	14,920	1.50	7.16	7.40	0.00	0.00	
4	31,670	1.54	7.02	—	18,970	15,300	1.50	7.15	7.30	0.00	0.00	
5	31,430	1.48	7.00	—	19,420	15,340	1.44	7.18	7.20	2.40	0.00	
6	31,680	1.80	6.96	—	19,330	15,770	1.50	7.16	7.00	0.00	0.00	
7	31,710	1.56	7.01	—	19,000	15,700	1.55	7.16	6.90	0.00	0.00	
8	31,120	1.54	7.01	—	18,500	15,320	1.53	7.17	6.90	0.00	0.00	
9	31,590	1.59	6.97	—	19,150	15,310	1.55	7.15	6.90	0.00	0.00	
10	31,470	1.60	7.02	—	18,860	15,530	1.53	7.18	6.80	0.00	0.00	
11	31,620	1.54	7.01	—	17,600	15,860	2.69	7.19	6.70	0.00	0.00	
12	31,460	1.53	7.00	—	17,370	15,810	1.34	7.22	6.60	2.40	0.00	
13	31,450	1.57	7.02	—	16,780	15,770	1.42	7.22	6.50	0.00	0.00	
14	31,850	1.57	7.05	—	16,420	15,930	1.43	7.22	6.40	0.00	0.00	
15	31,740	1.63	7.02	—	17,270	15,470	1.53	7.23	6.10	0.00	0.00	
16	31,230	1.68	7.06	—	16,000	15,100	1.56	7.25	6.00	0.00	0.00	
17	31,380	1.71	7.07	—	16,990	15,890	1.57	7.26	6.00	0.00	0.00	
18	32,570	1.68	7.06	—	17,150	16,180	1.57	7.25	6.00	0.00	0.00	
19	33,120	1.62	7.05	—	17,980	15,990	1.59	7.28	5.90	2.40	0.00	
20	33,260	1.81	7.09	—	19,130	15,970	1.77	7.28	5.80	0.00	0.00	
21	32,900	1.71	7.04	—	19,840	15,670	1.69	7.23	5.70	0.00	0.00	
22	33,880	1.76	7.09	—	20,440	15,600	1.71	7.31	5.20	0.00	0.00	
23	32,710	1.98	7.04	—	19,850	15,110	1.72	7.28	5.30	0.00	0.00	
24	33,650	1.83	7.07	—	20,060	15,950	1.72	7.29	5.50	0.00	0.00	
25	33,810	1.91	7.07	—	20,240	16,140	1.87	7.29	5.40	0.00	0.00	
26	31,790	1.91	7.05	—	17,890	15,210	1.88	7.25	5.30	2.40	0.00	
27	34,350	2.07	7.13	—	18,670	15,830	1.96	7.28	5.30	0.00	0.00	
28	36,620	2.03	7.07	—	23,250	20,010	2.00	7.26	5.20	0.00	0.00	
29	36,490	1.99	7.10	—	22,700	19,430	2.01	7.27	5.20	0.00	0.00	
30	36,340	2.10	7.12	—	22,960	19,600	2.08	7.26	5.30	0.00	0.00	
31	36,280	2.15	7.06	—	23,140	19,930	2.03	7.25	5.20	0.00	0.00	
最大	36,620	2.15	7.13	—	23,250	20,010	2.69	7.31	7.50	2.40	0.00	
最小	31,080	1.48	6.96	—	16,000	14,920	1.34	7.15	5.20	0.00	0.00	
合計	1,081,390			—	631,880	500,080				9.60	0.00	
平均	34,884	1.73	7.04	—	20,383	16,132	1.69	7.23	6.19	0.31	0.00	

初野浄水場 流量水質報告書

平成29年2月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	36,280	2.09	7.10	—	22,830	19,940	2.07	7.28	5.10	0.00	0.00	
2	36,370	2.11	7.11	—	22,710	21,030	2.03	7.28	4.90	2.40	0.00	
3	36,410	2.38	7.11	—	22,980	21,290	2.34	7.29	5.00	0.00	0.00	
4	36,250	2.66	7.15	—	22,770	21,120	2.65	7.30	4.90	0.00	0.00	
5	37,200	2.56	7.18	—	23,620	21,300	2.64	7.30	5.00	0.00	0.00	
6	35,720	2.55	7.15	—	22,990	20,540	2.67	7.30	5.10	0.00	0.00	
7	36,350	2.67	7.16	—	23,470	21,200	2.81	7.31	5.00	0.00	0.00	
8	36,420	2.80	7.15	—	23,190	21,260	2.73	7.31	4.80	0.00	0.00	
9	36,460	2.62	7.16	—	23,240	21,230	2.71	7.31	4.80	2.40	0.00	
10	36,380	2.68	7.12	—	23,330	21,220	2.64	7.29	4.80	0.00	0.00	
11	36,750	2.59	7.13	—	23,480	21,370	2.68	7.31	4.70	0.00	0.00	
12	36,040	2.58	7.18	—	22,920	20,670	2.67	7.33	4.70	0.00	0.00	
13	36,340	2.62	7.19	—	23,040	20,830	2.60	7.33	4.60	0.00	0.00	
14	35,370	1.96	7.56	—	23,300	21,330	1.37	7.60	4.60	0.00	0.00	
15	36,680	2.00	7.53	—	22,500	20,750	1.38	7.60	4.80	0.00	0.00	
16	35,530	1.95	7.52	—	22,710	20,780	1.38	7.57	4.80	2.40	0.00	
17	37,290	1.92	7.52	—	23,350	21,910	1.40	7.58	5.00	0.00	0.00	
18	33,290	2.05	7.51	—	21,140	19,040	1.30	7.55	5.00	0.00	0.00	
19	36,750	2.24	7.50	—	23,610	20,580	1.51	7.57	4.90	0.00	0.00	
20	36,140	2.08	7.52	—	23,280	20,290	1.45	7.51	4.80	0.00	0.00	
21	36,350	2.08	7.49	—	23,230	21,060	1.50	7.53	4.80	0.00	0.00	
22	31,620	2.04	7.52	—	18,000	16,130	1.36	7.57	4.70	0.00	0.00	
23	31,840	1.90	7.50	—	17,710	16,110	1.38	7.53	4.80	2.40	0.00	
24	31,690	1.91	7.50	—	18,060	15,960	1.37	7.55	4.80	0.00	0.00	
25	31,270	2.01	7.53	—	17,470	15,710	1.38	7.54	4.80	0.00	0.00	
26	32,020	1.89	7.52	—	18,250	15,710	1.36	7.52	4.80	0.00	0.00	
27	31,210	1.80	7.53	—	17,770	15,100	1.28	7.52	4.90	0.00	0.00	
28	30,200	1.81	7.52	—	18,450	16,220	1.23	7.51	4.90	0.00	0.00	
最大	37,290	2.80	7.56	—	23,620	21,910	2.81	7.60	5.10	2.40	0.00	
最小	30,200	1.80	7.10	—	17,470	15,100	1.23	7.28	4.60	0.00	0.00	
合計	1,047,710			—	650,490	586,690				9.60	0.00	
平均	37,418	2.23	7.35	—	23,232	20,953	1.92	7.44	4.85	0.34	0.00	

初野浄水場 流量水質報告書

平成28年3月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	30,990	3.23	7.30	—	18,030	16,010	2.20	7.37	5.30	0.00	0.00	
2	31,310	3.28	7.31	—	18,200	16,200	2.29	7.38	5.20	2.25	0.00	
3	31,510	3.23	7.33	—	18,250	16,280	2.23	7.40	5.30	0.00	0.00	
4	31,740	3.37	7.35	—	18,240	16,390	2.24	7.39	5.40	0.00	0.00	
5	32,360	3.45	7.32	—	18,360	16,560	2.27	7.40	5.40	0.00	0.00	
6	30,630	3.42	7.30	—	17,770	15,300	2.30	7.35	5.50	0.00	0.00	
7	31,300	3.12	7.32	—	18,610	15,590	2.23	7.35	5.70	0.00	0.00	
8	31,000	8.54	7.29	—	17,910	16,010	2.26	7.35	6.00	0.00	0.00	
9	32,310	4.23	7.36	—	18,740	16,770	2.93	7.41	6.10	2.40	0.00	
10	30,520	3.47	7.30	—	17,150	15,720	2.49	7.39	5.90	0.00	0.00	
11	32,490	3.17	7.28	—	18,970	16,360	2.22	7.35	5.50	0.00	0.00	
12	31,770	3.07	7.31	—	18,750	15,980	2.19	7.37	5.50	0.00	0.00	
13	32,720	3.03	7.29	—	19,190	15,980	2.14	7.35	5.60	0.00	0.00	
14	32,340	3.00	7.30	—	19,200	15,820	2.07	7.37	5.60	0.00	0.00	
15	31,020	2.99	7.30	—	18,170	15,570	2.11	7.35	5.70	0.00	0.00	
16	33,060	3.04	7.35	—	19,320	16,770	2.10	7.42	6.10	2.40	0.00	
17	31,230	2.88	7.44	—	18,430	15,730	2.08	7.46	6.40	0.00	0.00	
18	31,750	2.84	7.43	—	18,620	16,060	2.03	7.45	6.80	0.00	0.00	
19	32,890	2.79	7.42	—	19,350	16,590	2.01	7.43	6.70	0.00	0.00	
20	30,810	2.88	7.47	—	18,280	15,220	2.03	7.48	7.50	0.00	0.00	
21	31,700	2.77	7.45	—	18,910	15,700	2.06	7.47	7.50	0.00	0.00	
22	31,980	2.79	7.38	—	19,100	15,990	2.08	7.48	7.40	0.00	0.00	
23	31,400	2.92	7.46	—	18,160	16,130	2.02	7.42	7.60	2.40	0.00	
24	31,970	2.93	7.47	—	18,960	16,490	2.05	7.48	7.70	0.00	0.00	
25	31,620	2.99	7.49	—	18,730	16,370	1.95	7.50	7.50	0.00	0.00	
26	31,440	2.98	7.48	—	19,030	16,210	1.90	7.49	7.50	0.00	0.00	
27	31,520	2.93	7.47	—	18,770	15,740	1.86	7.48	7.50	0.00	0.00	
28	32,200	2.96	7.47	—	18,820	16,140	1.84	7.47	7.40	0.00	0.00	
29	30,810	3.01	7.49	—	18,270	16,090	1.76	7.48	7.50	2.40	0.00	
30	31,560	3.01	7.52	—	18,300	16,370	1.85	7.49	7.60	0.00	0.00	
31	31,470	2.24	7.50	—	18,150	16,310	1.61	7.50	8.00	0.00	0.00	
最大	981,420			—	574,740	498,450				11.85	0.00	
最少	33,060	8.54	7.52	—	19,350	16,770	2.93	7.50	8.00	2.40	0.00	
合計	30,520	2.24	7.28	—	17,150	15,220	1.61	7.35	5.20	0.00	0.00	
平均	31,659	3.24	7.39	—	18,540	16,079	2.11	7.42	6.46	0.38	0.00	