

## 初野浄水場 流量水質報告書

令和2年4月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	33,350	17.19	7.49	—	19,650	16,380	3.96	7.00	7.90	449.30	0.00	
2	32,930	16.74	7.51	—	20,270	16,350	3.00	7.02	8.30	449.30	0.00	
3	32,630	16.93	7.54	—	19,660	16,610	3.69	7.03	8.70	449.30	0.00	
4	33,600	16.76	7.52	—	20,260	16,950	3.82	7.07	8.80	449.30	0.00	
5	32,550	16.59	7.56	—	19,650	16,090	3.35	7.07	8.50	449.30	0.00	
6	32,410	16.33	7.54	—	20,070	17,720	3.77	7.06	8.90	449.30	0.00	
7	36,140	16.46	7.54	—	23,240	21,330	5.44	7.06	8.90	449.30	0.00	
8	36,590	16.23	7.51	—	22,520	20,290	5.20	7.03	8.80	449.30	0.00	
9	36,460	15.88	7.52	—	23,030	20,970	4.38	7.06	8.80	449.30	0.00	
10	35,300	15.84	7.54	—	22,050	20,360	4.97	7.08	9.30	449.30	0.00	
11	36,010	15.71	7.53	—	22,930	21,040	5.20	7.07	9.40	449.30	0.00	
12	35,800	15.47	7.52	—	22,160	20,150	4.44	7.01	9.10	449.30	0.00	
13	35,510	15.30	7.49	—	23,360	19,700	4.25	7.05	9.30	449.30	0.00	
14	35,990	15.49	7.45	—	23,280	20,300	5.04	7.07	8.90	449.30	0.00	
15	35,540	15.50	7.48	—	22,730	20,670	4.73	7.05	9.20	449.30	0.00	
16	35,070	15.61	7.46	—	21,950	20,400	4.53	6.99	9.50	449.30	0.00	
17	35,260	15.21	7.40	—	22,890	20,270	4.81	6.98	9.10	449.30	0.00	
18	35,600	14.81	7.44	—	22,690	20,710	4.26	7.01	9.20	449.30	0.00	
19	35,290	15.08	7.43	—	22,770	19,900	4.02	6.84	9.00	449.30	0.00	
20	36,310	15.61	7.38	—	23,660	20,450	4.89	6.96	9.30	449.30	0.00	
21	34,080	17.83	7.41	—	21,980	19,740	5.07	6.94	9.40	449.30	0.00	
22	36,020	18.64	7.41	—	22,540	21,340	5.63	6.98	9.90	449.30	0.00	
23	34,020	18.97	7.40	—	21,620	20,110	5.69	6.92	10.00	449.30	0.00	
24	36,310	19.61	7.39	—	23,090	21,330	5.65	6.97	9.90	449.30	0.00	
25	34,350	20.35	7.38	—	21,940	20,070	5.89	7.01	9.70	449.30	0.00	
26	35,770	20.26	7.39	—	22,630	20,380	5.91	6.98	9.60	449.30	0.00	
27	36,200	18.73	7.40	—	23,190	20,550	5.38	6.97	10.80	449.30	0.00	
28	35,960	19.02	7.43	—	23,240	20,470	5.48	6.95	10.70	449.30	0.00	
29	36,280	18.17	7.41	—	22,990	21,130	5.38	6.98	10.50	449.30	0.00	
30	36,060	18.24	7.42	—	22,620	20,930	5.49	7.02	11.10	449.30	0.00	
合計	1,053,390	—	—	—	664,660	592,690	—	—	—	13,479.00	0.00	
最大	36,590	20.35	7.56	—	23,660	21,340	5.91	7.08	11.10	449.30	0.00	
最小	32,410	14.81	7.38	—	19,650	16,090	3.00	6.84	7.90	449.30	0.00	
平均	35,113	16.95	7.46	—	22,155	19,756	4.78	7.01	9.35	449.30	0.00	

## 初野浄水場 流量水質報告書

令和2年5月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	34,600	17.22	7.21	—	21,760	20,300	4.64	6.89	14.30	449.30	0.00	
2	33,600	16.48	7.42	—	20,730	18,410	4.53	6.94	11.40	449.30	0.00	
3	35,300	15.69	7.41	—	22,100	20,260	4.13	6.90	11.80	449.30	0.00	
4	36,250	15.43	7.42	—	23,260	19,950	4.06	6.90	12.00	449.30	0.00	
5	36,260	13.65	7.46	—	23,490	20,240	4.14	6.95	12.50	449.30	0.00	
6	36,010	13.36	7.44	—	23,350	19,910	3.87	6.92	12.20	449.30	0.00	
7	35,980	12.21	7.44	—	23,780	19,730	4.04	6.94	12.40	449.30	0.00	
8	36,080	12.00	7.42	—	23,280	20,330	3.42	6.93	12.60	449.30	0.00	
9	36,770	10.80	7.43	—	23,170	20,910	3.09	6.90	12.80	449.30	0.00	
10	34,990	10.49	7.38	—	22,850	19,880	3.66	6.91	12.90	449.30	0.00	
11	35,550	9.62	7.42	—	23,400	20,200	3.23	6.94	13.40	449.30	0.00	
12	36,070	9.55	7.41	—	22,900	21,450	3.30	6.91	13.80	449.30	0.00	
13	35,470	9.01	7.39	—	22,170	20,460	6.90	7.31	13.60	0.00	0.00	
14	36,590	8.91	7.38	—	23,650	21,560	5.75	7.37	15.20	0.00	0.00	
15	35,290	7.97	7.37	—	21,890	20,430	5.90	7.32	14.60	0.00	0.00	
16	36,030	7.72	7.36	—	23,460	20,380	5.70	7.29	14.10	0.00	0.00	
17	36,010	7.27	7.37	—	23,810	19,820	5.44	7.30	14.30	0.00	0.00	
18	36,010	7.32	7.35	—	23,000	19,800	5.45	7.30	14.20	0.00	0.00	
19	35,950	6.90	7.33	—	23,580	20,110	5.10	7.26	14.00	0.00	0.00	
20	34,730	7.30	7.28	—	22,640	19,570	4.93	7.24	13.50	0.00	0.00	
21	34,920	6.96	7.27	—	22,500	19,710	4.75	7.22	13.30	0.00	0.00	
22	34,830	6.77	7.28	—	22,610	19,870	4.85	7.21	13.20	0.00	0.00	
23	35,090	6.73	7.26	—	22,360	20,080	4.72	7.22	13.30	0.00	0.00	
24	34,340	6.53	7.28	—	22,360	19,450	4.62	7.19	13.50	0.00	0.00	
25	34,790	6.30	7.30	—	22,190	19,880	4.49	7.21	13.80	0.00	0.00	
26	34,570	6.42	7.28	—	21,790	20,430	4.42	7.23	14.50	0.00	0.00	
27	35,620	6.37	7.30	—	22,520	20,020	4.45	7.24	14.40	0.00	0.00	
28	35,860	6.34	7.26	—	23,330	20,410	4.64	7.20	15.20	0.00	0.00	
29	35,890	6.49	7.27	—	22,570	20,280	4.44	7.22	15.20	0.00	0.00	
30	35,990	6.42	7.25	—	23,450	20,500	4.53	7.22	15.30	0.00	0.00	
31	35,430	6.46	7.23	—	22,710	19,830	4.52	7.20	15.60	0.00	0.00	
合計	1,100,870	—	—	—	706,660	624,160	—	—	—	5,391.60	0.00	
最大	36,770	17.22	7.46	—	23,810	21,560	6.90	7.37	15.60	449.30	0.00	
最小	33,600	6.30	7.21	—	20,730	18,410	3.09	6.89	11.40	0.00	0.00	
平均	35,512	9.38	7.34	—	22,795	20,134	4.57	7.12	13.64	173.92	0.00	

## 初野浄水場 流量水質報告書

令和2年6月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	35,800	6.54	7.22	—	23,420	20,240	4.60	7.17	16.00	0.00	0.00	
2	35,460	7.45	7.23	—	22,860	20,430	5.25	7.14	15.60	0.00	0.00	
3	35,420	7.66	7.21	—	22,570	20,450	5.47	7.14	15.70	0.00	0.00	
4	35,600	8.08	7.19	—	22,550	20,410	5.59	7.14	15.90	0.00	0.00	
5	35,570	8.38	7.20	—	22,890	20,440	5.73	7.10	16.20	0.00	0.00	
6	36,420	8.46	7.19	—	22,850	20,730	6.06	7.09	16.40	0.00	0.00	
7	36,090	8.48	7.19	—	23,770	19,730	6.09	7.07	16.30	0.00	0.00	
8	35,900	7.11	7.15	—	22,660	19,770	4.97	7.09	16.40	0.00	0.00	
9	36,590	7.51	7.20	—	23,700	20,880	5.22	7.11	16.70	0.00	0.00	
10	36,410	8.34	7.19	—	22,790	20,760	5.43	7.10	16.80	0.00	0.00	
11	35,270	7.50	7.24	—	22,310	20,210	4.83	7.14	18.30	0.00	0.00	
12	36,270	7.84	7.24	—	23,820	20,900	5.09	7.11	18.30	0.00	0.00	
13	35,620	8.80	7.21	—	23,240	20,880	5.79	7.11	17.40	0.00	0.00	
14	35,850	9.01	7.23	—	24,000	20,120	5.96	7.14	17.30	0.00	0.00	
15	35,030	7.74	7.22	—	23,250	20,040	5.83	7.14	17.40	0.00	0.00	
16	34,720	8.45	7.19	—	22,540	20,710	5.94	7.09	17.40	0.00	0.00	
17	31,620	9.04	7.12	—	20,000	18,510	6.60	7.08	15.80	0.00	0.00	
18	35,440	9.12	7.12	—	22,500	20,650	5.95	7.10	15.80	0.00	0.00	
19	32,880	9.09	7.12	—	21,480	19,010	6.00	7.08	15.70	0.00	0.00	
20	35,670	9.02	7.14	—	23,450	20,690	5.91	7.09	15.90	0.00	0.00	
21	35,850	9.19	7.14	—	23,420	20,500	5.91	7.12	16.00	0.00	0.00	
22	35,670	9.10	7.10	—	23,810	19,720	5.89	7.07	15.90	0.00	0.00	
23	36,330	8.56	7.11	—	23,950	20,740	5.85	7.10	15.70	0.00	0.00	
24	32,260	8.68	7.10	—	20,960	18,630	5.62	7.08	15.80	0.00	0.00	
25	35,460	8.77	7.09	—	23,110	20,330	5.97	7.07	15.70	0.00	0.00	
26	36,010	8.53	7.08	—	23,970	20,620	5.73	7.05	15.70	0.00	0.00	
27	35,810	9.23	7.12	—	23,870	20,300	5.85	7.07	15.90	0.00	0.00	
28	35,280	8.74	7.11	—	23,010	20,380	6.00	7.04	15.90	0.00	0.00	
29	36,860	8.80	7.12	—	24,290	20,890	6.04	7.07	16.00	0.00	0.00	
30	34,430	8.73	7.14	—	22,430	20,010	6.03	7.06	15.90	0.00	0.00	
合計	1,061,590	—	—	—	689,470	607,680	—	—	—	0.00	0.00	
最大	36,860	9.23	7.24	—	24,290	20,900	6.60	7.17	18.30	0.00	0.00	
最小	31,620	6.54	7.08	—	20,000	18,510	4.60	7.04	15.60	0.00	0.00	
平均	35,386	8.40	7.16	—	22,982	20,256	5.71	7.10	16.33	0.00	0.00	

## 初野浄水場 流量水質報告書

令和2年7月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	35,540	8.44	7.16	—	23,290	20,620	6.09	7.02	15.90	0.00	0.00	
2	36,320	8.22	7.14	—	23,840	21,060	6.10	7.04	16.00	0.00	0.00	
3	35,750	8.00	7.15	—	22,630	20,910	6.27	7.08	16.10	0.00	0.00	
4	36,220	8.02	7.11	—	23,650	21,010	5.89	7.04	15.90	0.00	0.00	
5	35,880	9.97	7.07	—	24,300	19,780	6.78	7.04	15.90	0.00	0.00	
6	35,700	8.45	7.08	—	24,170	19,440	6.13	6.99	15.90	0.00	0.00	
7	35,850	7.27	7.09	—	23,720	20,110	5.17	7.01	18.10	0.00	0.00	
8	35,360	5.02	7.14	—	22,980	20,490	4.07	7.05	18.60	0.00	0.00	
9	34,970	5.25	7.16	—	23,060	20,100	4.49	7.03	18.60	0.00	0.00	
10	35,610	5.38	7.13	—	22,560	20,490	4.62	7.01	18.70	0.00	0.00	
11	35,580	5.36	7.10	—	22,990	20,760	4.36	7.01	18.70	0.00	0.00	
12	34,750	6.92	7.10	—	23,090	19,580	6.19	7.08	19.00	0.00	0.00	
13	35,270	5.30	7.15	—	23,300	19,540	4.83	7.08	18.60	0.00	0.00	
14	34,920	5.05	7.12	—	23,100	19,800	4.53	7.03	18.50	0.00	0.00	
15	34,340	5.27	7.07	—	22,770	19,490	4.89	7.03	18.30	0.00	0.00	
16	35,960	5.31	7.01	—	23,860	20,430	4.81	7.00	17.90	0.00	0.00	
17	35,520	5.67	7.01	—	23,430	20,620	5.20	6.97	17.80	0.00	0.00	
18	35,480	5.47	7.03	—	22,960	20,950	5.20	6.99	17.60	0.00	0.00	
19	35,140	5.55	7.02	—	23,310	20,280	5.13	6.95	17.70	0.00	0.00	
20	34,300	5.27	7.06	—	22,040	19,830	4.96	7.00	17.80	0.00	0.00	
21	35,580	5.11	7.04	—	23,040	21,140	4.88	6.99	17.90	0.00	0.00	
22	36,360	5.78	7.06	—	23,710	21,050	5.08	7.02	17.30	0.00	0.00	
23	34,850	5.21	7.08	—	22,210	20,290	4.62	7.01	18.50	0.00	0.00	
24	35,890	5.35	7.09	—	23,100	20,130	4.50	7.06	18.80	0.00	0.00	
25	35,710	5.13	7.09	—	23,580	20,070	4.51	7.06	18.80	0.00	0.00	
26	35,420	5.32	7.08	—	23,620	19,900	5.18	7.03	18.60	0.00	0.00	
27	36,500	5.76	7.07	—	24,690	20,020	5.11	7.01	18.60	0.00	0.00	
28	34,650	5.00	7.07	—	23,010	19,660	4.60	7.02	18.80	0.00	0.00	
29	35,870	10.75	7.03	—	23,810	19,770	7.78	6.99	18.20	0.00	0.00	
30	35,930	15.51	7.07	—	24,010	19,890	9.45	6.75	18.00	314.50	0.00	
31	35,760	15.09	7.05	—	23,160	19,990	6.72	6.68	17.70	314.50	0.00	
合計	1,100,980	—	—	—	722,990	627,200	—	—	—	629.00	0.00	
最大	36,500	15.51	7.16	—	24,690	21,140	9.45	7.08	19.00	314.50	0.00	
最小	34,300	5.00	7.01	—	22,040	19,440	4.07	6.68	15.90	0.00	0.00	
平均	35,515	6.88	7.08	—	23,322	20,232	5.42	7.00	17.83	20.29	0.00	

## 初野浄水場 流量水質報告書

令和2年8月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	35,580	14.93	7.04	—	23,530	20,170	7.09	6.70	17.70	458.00	0.00	
2	35,830	12.77	7.08	—	23,390	20,260	5.73	6.70	17.90	458.00	0.00	
3	36,140	11.70	7.10	—	23,030	20,180	4.78	6.71	18.20	458.00	0.00	
4	35,460	10.70	7.11	—	22,440	20,640	4.11	6.69	18.40	458.00	0.00	
5	37,000	15.04	7.07	—	23,360	20,890	4.38	6.70	18.80	458.00	0.00	
6	36,890	7.68	7.09	—	23,190	20,760	3.66	6.77	19.10	152.00	0.00	
7	38,290	6.25	7.10	—	23,320	21,910	5.35	7.02	18.60	0.00	0.00	
8	37,610	5.74	7.12	—	22,800	20,940	4.64	7.04	18.50	0.00	0.00	
9	37,080	5.72	7.09	—	24,870	20,010	4.75	7.00	18.20	0.00	0.00	
10	36,520	5.16	7.09	—	24,360	19,680	4.12	7.02	18.40	0.00	0.00	
11	37,770	5.08	7.03	—	23,760	20,920	3.94	7.02	18.70	0.00	0.00	
12	37,290	5.10	7.06	—	23,270	21,000	3.94	7.06	18.80	0.00	0.00	
13	36,120	4.74	7.09	—	22,770	20,400	3.61	7.03	18.90	0.00	0.00	
14	35,920	4.75	7.09	—	23,060	20,000	3.66	7.04	18.90	0.00	0.00	
15	37,210	4.75	7.07	—	23,680	20,580	3.69	7.03	19.00	0.00	0.00	
16	36,370	4.84	7.07	—	23,150	20,260	3.83	7.04	19.20	0.00	0.00	
17	36,120	4.84	7.04	—	23,580	20,180	3.91	6.97	19.10	0.00	0.00	
18	36,320	4.75	6.99	—	23,200	20,820	3.87	7.03	19.20	0.00	0.00	
19	35,620	4.83	6.99	—	22,670	20,680	4.31	7.00	19.20	0.00	0.00	
20	38,480	5.55	6.91	—	23,890	21,240	4.25	6.91	17.20	0.00	0.00	
21	36,620	5.74	6.93	—	23,430	20,530	4.21	6.95	17.20	0.00	0.00	
22	39,180	4.37	6.98	—	25,130	22,100	3.42	6.94	19.20	0.00	0.00	
23	36,060	4.46	6.96	—	23,840	19,260	3.42	6.92	19.40	0.00	0.00	
24	37,240	4.37	6.95	—	24,080	20,110	3.49	6.97	19.60	0.00	0.00	
25	37,320	4.40	6.94	—	23,880	20,700	3.49	6.97	19.70	0.00	0.00	
26	37,060	4.39	6.96	—	24,140	20,400	3.47	6.97	19.70	0.00	0.00	
27	37,090	4.20	6.94	—	24,290	20,710	3.48	6.94	19.90	0.00	0.00	
28	38,170	4.11	6.96	—	24,090	21,400	3.36	6.92	20.20	0.00	0.00	
29	36,560	3.99	6.95	—	23,280	20,540	3.33	6.92	20.40	0.00	0.00	
30	33,000	3.96	6.93	—	23,800	20,000	3.02	6.89	20.30	0.00	0.00	
31	41,000	3.74	6.91	—	24,150	19,880	2.81	6.92	20.00	0.00	0.00	
合計	1,142,920	—	—	—	731,430	637,150	—	—	—	2,442.00	0.00	
最大	41,000	15.04	7.12	—	25,130	22,100	7.09	7.06	20.40	458.00	0.00	
最小	33,000	3.74	6.91	—	22,440	19,260	2.81	6.69	17.20	0.00	0.00	
平均	36,868	6.21	7.02	—	23,595	20,553	4.04	6.93	18.95	78.77	0.00	

## 初野浄水場 流量水質報告書

令和2年9月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	36,430	3.72	6.91	—	24,400	19,520	2.73	6.92	19.70	0.00	0.00	
2	36,060	3.70	6.91	—	24,220	19,820	2.40	6.93	19.60	0.00	0.00	
3	39,360	3.45	6.89	—	26,090	22,210	2.12	6.91	20.90	0.00	0.00	
4	34,530	3.21	6.95	—	22,660	19,730	2.07	6.95	21.20	0.00	0.00	
5	38,450	3.56	6.93	—	25,380	21,570	2.18	6.95	21.30	0.00	0.00	
6	37,240	3.31	6.93	—	25,600	20,360	2.29	6.94	21.10	0.00	0.00	
7	36,420	3.25	6.95	—	24,800	19,640	2.33	6.91	21.10	0.00	0.00	
8	37,600	2.94	6.93	—	25,170	21,670	2.26	6.96	20.10	0.00	0.00	
9	37,910	3.06	6.89	—	24,640	21,620	2.35	6.97	20.10	0.00	0.00	
10	38,060	3.09	6.95	—	24,590	21,320	2.44	6.97	20.10	0.00	0.00	
11	36,540	3.31	6.92	—	23,700	20,930	2.54	6.95	20.00	0.00	0.00	
12	38,310	3.07	6.90	—	25,500	22,710	2.36	7.02	21.20	0.00	0.00	
13	35,830	3.04	6.95	—	24,430	17,720	2.50	7.01	21.20	0.00	0.00	
14	37,350	3.01	6.91	—	25,100	19,900	2.50	6.93	20.80	0.00	0.00	
15	36,520	3.17	6.92	—	24,590	20,120	2.69	6.95	20.80	0.00	0.00	
16	37,520	3.52	6.86	—	25,200	20,910	2.99	6.91	18.90	0.00	0.00	
17	37,270	3.67	6.91	—	24,890	20,950	3.05	6.86	18.80	0.00	0.00	
18	37,290	3.74	6.88	—	24,410	20,780	3.18	6.86	18.80	0.00	0.00	
19	37,120	3.58	6.90	—	24,660	21,110	3.24	6.84	18.80	0.00	0.00	
20	37,110	3.73	6.93	—	24,780	20,580	3.24	6.82	18.60	0.00	0.00	
21	37,670	3.73	6.93	—	25,350	19,760	3.25	6.82	18.50	0.00	0.00	
22	36,990	3.72	6.94	—	25,120	20,980	3.30	6.83	18.50	0.00	0.00	
23	35,730	3.23	6.80	—	24,210	19,370	3.03	6.72	19.70	0.00	0.00	
24	37,000	3.38	6.77	—	24,280	21,110	2.98	6.71	19.70	0.00	0.00	
25	37,490	3.99	6.82	—	25,740	20,780	3.52	6.73	17.90	0.00	0.00	
26	38,610	4.20	6.81	—	25,930	20,460	2.90	6.76	19.00	0.00	0.00	
27	35,840	8.65	6.85	—	24,170	19,980	7.68	6.78	18.30	0.00	0.00	
28	36,670	7.83	6.86	—	24,440	19,850	7.54	6.81	18.20	0.00	0.00	
29	36,950	7.54	6.87	—	24,490	20,330	6.29	6.78	18.10	0.00	0.00	
30	37,210	7.08	6.89	—	23,860	20,000	6.24	6.80	17.90	0.00	0.00	
合計	1,113,080	—	—	—	742,400	615,790	—	—	—	0.00	0.00	
最大	39,360	8.65	6.95	—	26,090	22,710	7.68	7.02	21.30	0.00	0.00	
最小	34,530	2.94	6.77	—	22,660	17,720	2.07	6.71	17.90	0.00	0.00	
平均	37,103	4.02	6.90	—	24,747	20,526	3.27	6.88	19.63	0.00	0.00	

## 初野浄水場 流量水質報告書

令和2年10月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	37,270	7.14	6.88	—	24,720	20,610	5.67	6.74	17.40	0.00	0.00	
2	37,690	6.84	6.87	—	23,040	20,400	5.30	6.76	17.30	0.00	0.00	
3	36,710	6.47	6.90	—	22,710	20,320	4.92	6.78	17.40	0.00	0.00	
4	37,390	6.20	6.92	—	22,140	20,620	4.55	6.78	17.40	0.00	0.00	
5	36,260	5.74	6.91	—	24,200	19,790	4.37	6.77	17.30	0.00	0.00	
6	36,000	5.51	6.93	—	24,050	20,430	3.87	6.82	15.90	0.00	0.00	
7	37,450	5.50	6.94	—	23,510	18,010	3.88	6.82	15.70	0.00	0.00	
8	35,900	5.62	6.92	—	22,640	19,700	4.05	6.80	15.60	0.00	0.00	
9	34,390	5.43	6.89	—	23,030	18,660	3.63	6.77	16.50	0.00	0.00	
10	37,530	5.65	6.86	—	24,550	20,600	3.75	6.78	16.40	0.00	0.00	
11	36,320	5.44	6.80	—	24,570	19,610	3.92	6.71	16.60	0.00	0.00	
12	36,790	6.06	6.75	—	25,070	19,620	4.18	6.67	16.60	0.00	0.00	
13	36,100	4.60	6.87	—	23,950	20,290	3.33	6.74	16.60	0.00	0.00	
14	36,120	4.42	6.87	—	24,510	20,120	3.08	6.81	16.60	0.00	0.00	
15	35,450	4.35	6.89	—	21,560	19,930	3.11	6.78	16.40	0.00	0.00	
16	37,540	4.43	6.90	—	24,280	20,640	2.90	6.85	16.40	0.00	0.00	
17	36,030	9.98	6.91	—	22,820	19,670	3.01	6.84	16.10	0.00	0.00	
18	35,760	4.38	6.90	—	24,100	19,820	2.98	6.85	16.00	0.00	0.00	
19	36,820	4.69	6.92	—	24,170	19,850	3.11	6.86	15.90	0.00	0.00	
20	35,440	5.01	6.90	—	22,970	19,740	3.19	6.86	15.00	0.00	0.00	
21	36,440	4.99	6.90	—	22,990	20,020	3.25	6.92	14.90	0.00	0.00	
22	35,770	4.89	6.91	—	23,190	19,140	3.28	6.98	14.90	0.00	0.00	
23	36,110	5.08	6.88	—	22,970	19,280	3.20	6.93	14.90	0.00	0.00	
24	36,550	4.86	6.82	—	23,670	19,670	3.11	6.94	14.80	0.00	0.00	
25	35,410	5.04	6.90	—	23,260	18,600	3.19	6.98	14.70	0.00	0.00	
26	35,640	5.08	6.93	—	23,140	19,500	3.51	7.03	14.60	0.00	0.00	
27	35,900	4.09	6.94	—	23,140	20,180	2.67	7.03	14.50	0.00	0.00	
28	35,940	3.96	6.94	—	23,120	20,040	2.71	7.07	14.40	0.00	0.00	
29	36,480	3.86	6.96	—	22,790	20,590	2.67	7.04	14.40	0.00	0.00	
30	36,180	3.66	6.98	—	23,370	20,280	2.68	6.97	14.20	0.00	0.00	
31	36,990	3.81	6.98	—	24,200	20,340	2.83	6.96	14.00	0.00	0.00	
合計	1,126,370	—	—	—	728,430	616,070	—	—	—	0.00	0.00	
最大	37,690	9.98	6.98	—	25,070	20,640	5.67	7.07	17.40	0.00	0.00	
最小	34,390	3.66	6.75	—	21,560	18,010	2.67	6.67	14.00	0.00	0.00	
平均	36,335	5.25	6.90	—	23,498	19,873	3.55	6.86	15.79	0.00	0.00	

## 初野浄水場 流量水質報告書

令和2年11月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	37,200	4.06	6.98	—	24,350	19,930	3.07	6.97	13.90	0.00	0.00	
2	35,840	4.27	6.95	—	24,090	19,230	3.07	7.03	13.90	0.00	0.00	
3	37,750	4.23	6.97	—	25,120	21,160	3.11	6.83	14.00	0.00	0.00	
4	36,200	4.59	7.01	—	23,360	20,270	3.15	7.00	13.80	0.00	0.00	
5	35,830	4.41	7.00	—	23,710	20,110	3.27	6.98	13.60	0.00	0.00	
6	36,760	4.79	7.02	—	23,740	20,310	3.38	6.99	13.60	0.00	0.00	
7	36,610	4.17	6.99	—	23,550	20,260	3.10	6.98	13.60	0.00	0.00	
8	36,270	4.11	6.96	—	23,770	20,260	3.00	6.98	13.60	0.00	0.00	
9	36,310	4.08	7.05	—	23,600	20,510	2.89	7.05	13.50	0.00	0.00	
10	36,540	4.14	7.05	—	23,930	20,380	3.08	7.15	13.10	0.00	0.00	
11	35,970	4.63	7.05	—	23,290	19,780	3.30	7.04	12.90	0.00	0.00	
12	36,850	4.53	7.05	—	23,890	20,170	3.46	7.04	12.60	0.00	0.00	
13	36,470	4.93	7.04	—	23,810	20,420	3.59	7.03	12.50	0.00	0.00	
14	36,930	5.09	7.03	—	23,680	21,010	3.90	7.02	12.50	0.00	0.00	
15	36,000	5.97	7.07	—	22,950	20,040	4.23	7.03	12.30	0.00	0.00	
16	37,300	5.09	7.05	—	24,070	20,760	3.65	7.14	12.40	0.00	0.00	
17	35,090	5.10	7.03	—	22,580	20,110	3.76	7.11	12.40	0.00	0.00	
18	36,220	5.23	7.03	—	23,240	20,220	3.92	7.06	12.30	0.00	0.00	
19	36,130	5.09	7.04	—	23,180	20,190	3.68	7.08	12.40	0.00	0.00	
20	36,230	5.06	7.04	—	23,170	20,780	3.65	7.03	12.80	0.00	0.00	
21	36,540	4.94	7.04	—	23,680	21,430	3.60	7.13	12.80	0.00	0.00	
22	35,550	4.90	7.07	—	23,500	19,760	3.58	7.13	12.60	0.00	0.00	
23	36,030	5.22	7.03	—	24,010	21,800	3.66	7.05	12.40	0.00	0.00	
24	35,730	4.66	7.09	—	23,270	19,160	3.46	7.17	12.20	0.00	0.00	
25	36,090	4.86	7.08	—	23,420	20,620	3.63	7.05	12.10	0.00	0.00	
26	35,540	5.18	7.06	—	23,240	19,920	3.78	7.04	12.00	0.00	0.00	
27	36,630	4.59	7.04	—	23,780	20,870	3.72	7.04	12.00	0.00	0.00	
28	37,040	4.75	7.01	—	23,960	20,930	3.97	7.00	11.90	0.00	0.00	
29	35,640	5.77	6.95	—	24,990	19,670	4.31	6.95	11.60	0.00	0.00	
30	36,080	6.41	6.89	—	24,420	19,970	4.59	6.90	11.30	0.00	0.00	
合計	1,089,370	—	—	—	711,350	610,030	—	—	—	0.00	0.00	
最大	37,750	6.41	7.09	—	25,120	21,800	4.59	7.17	14.00	0.00	0.00	
最小	35,090	4.06	6.89	—	22,580	19,160	2.89	6.83	11.30	0.00	0.00	
平均	36,312	4.83	7.02	—	23,712	20,334	3.55	7.03	12.75	0.00	0.00	



## 初野浄水場 流量水質報告書

令和2年12月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	36,270	6.81	6.84	—	24,030	20,380	5.23	6.79	10.80	0.00	0.00	
2	35,520	7.11	6.82	—	23,020	19,680	5.49	6.95	10.50	0.00	0.00	
3	37,250	5.62	3.69	—	24,060	20,860	3.69	7.07	10.70	0.00	0.00	
4	37,600	6.16	6.84	—	24,990	21,210	4.30	6.84	10.20	0.00	0.00	
5	35,490	6.98	6.83	—	22,900	20,040	4.65	6.84	10.00	0.00	0.00	
6	36,550	6.74	6.82	—	24,570	20,120	4.89	6.84	9.90	0.00	0.00	
7	36,340	7.21	6.84	—	23,790	19,840	4.97	6.88	9.90	0.00	0.00	
8	35,430	4.75	6.99	—	23,340	20,440	3.51	7.11	10.50	0.00	0.00	
9	35,370	6.70	6.78	—	22,900	20,090	4.40	7.03	9.90	0.00	0.00	
10	36,450	7.00	6.84	—	23,380	20,700	4.92	6.99	9.60	0.00	0.00	
11	36,960	7.55	6.82	—	23,930	21,320	5.40	6.80	9.60	0.00	0.00	
12	36,170	7.45	6.82	—	23,230	21,290	4.63	6.90	9.80	0.00	0.00	
13	35,580	7.20	6.83	—	23,790	20,800	4.40	6.92	9.80	0.00	0.00	
14	35,860	7.55	6.83	—	23,840	20,510	5.63	6.82	9.30	0.00	0.00	
15	36,220	10.81	6.60	—	23,480	21,430	7.90	6.58	8.40	0.00	0.00	
16	36,230	9.99	6.65	—	23,750	21,720	7.47	6.66	8.40	0.00	0.00	
17	35,890	5.68	6.97	—	22,700	21,220	3.90	7.01	9.00	0.00	0.00	
18	36,140	6.86	6.86	—	23,180	21,780	4.85	6.90	8.60	0.00	0.00	
19	36,270	9.41	6.76	—	23,510	21,800	7.36	6.79	8.50	0.00	0.00	
20	35,900	6.52	6.94	—	23,440	21,040	4.89	6.94	8.40	0.00	0.00	
21	35,720	6.30	6.99	—	23,400	20,880	4.88	7.11	8.20	0.00	0.00	
22	36,220	5.74	6.97	—	23,390	22,010	4.24	7.10	8.10	0.00	0.00	
23	36,280	5.99	6.98	—	23,470	21,570	4.30	6.97	8.00	0.00	0.00	
24	37,050	5.59	6.98	—	23,810	21,730	4.24	7.01	8.00	0.00	0.00	
25	36,670	4.96	6.98	—	23,760	21,950	3.57	7.16	8.10	0.00	0.00	
26	37,440	5.11	6.97	—	24,200	21,960	3.80	6.99	7.90	0.00	0.00	
27	36,230	5.59	7.03	—	23,840	21,030	3.88	7.00	7.80	0.00	0.00	
28	36,680	6.97	6.95	—	24,370	21,120	5.06	6.98	7.70	0.00	0.00	
29	37,130	6.81	6.96	—	24,250	21,030	5.43	7.00	7.70	0.00	0.00	
30	36,670	5.88	6.99	—	24,210	21,590	4.63	6.99	7.60	0.00	0.00	
31	36,420	5.49	7.00	—	24,330	20,740	4.08	7.05	7.30	0.00	0.00	
合計	1,126,000	—	—	—	734,860	651,880	—	—	—	0.00	0.00	
最大	37,600	10.81	7.03	—	24,990	22,010	7.90	7.16	10.80	0.00	0.00	
最小	35,370	4.75	3.69	—	22,700	19,680	3.51	6.58	7.30	0.00	0.00	
平均	36,323	6.73	6.78	—	23,705	21,028	4.86	6.94	8.97	0.00	0.00	

## 初野浄水場 流量水質報告書

令和3年1月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	37,030	5.18	7.06	—	23,750	21,300	3.86	7.08	7.20	0.00	0.00	
2	36,720	5.47	7.04	—	25,240	21,290	3.86	7.04	7.10	0.00	0.00	
3	36,640	5.42	7.07	—	24,870	21,060	4.04	7.14	6.90	0.00	0.00	
4	38,370	5.37	7.05	—	25,220	22,260	4.04	7.10	6.90	0.00	0.00	
5	34,950	5.84	7.05	—	23,120	20,310	4.33	7.14	6.80	0.00	0.00	
6	36,970	6.18	7.04	—	24,360	21,330	4.78	7.04	6.60	0.00	0.00	
7	36,600	5.82	7.09	—	23,580	21,520	4.56	7.08	6.50	0.00	0.00	
8	36,760	5.20	7.08	—	23,330	21,800	4.06	7.11	6.50	0.00	0.00	
9	37,480	5.19	7.10	—	24,270	21,860	4.03	7.14	6.30	0.00	0.00	
10	36,270	5.45	7.13	—	23,480	20,920	4.03	7.12	6.20	0.00	0.00	
11	38,110	5.48	7.13	—	23,400	21,160	4.26	7.12	6.10	0.00	0.00	
12	38,810	5.44	7.11	—	23,900	21,380	4.07	7.11	6.00	0.00	0.00	
13	37,560	5.77	7.12	—	23,310	21,120	7.20	7.13	6.00	0.00	0.00	
14	38,730	5.65	7.12	—	24,290	21,940	4.47	7.11	5.90	0.00	0.00	
15	38,240	5.31	7.10	—	24,450	22,050	4.22	7.10	5.80	0.00	0.00	
16	38,520	5.34	7.11	—	24,190	21,620	4.12	7.10	5.80	0.00	0.00	
17	38,240	5.30	7.09	—	25,340	21,460	4.10	7.12	5.80	0.00	0.00	
18	38,140	4.94	7.12	—	25,580	21,210	3.90	7.19	5.40	0.00	0.00	
19	37,930	4.91	7.15	—	24,520	21,580	3.83	7.20	5.30	0.00	0.00	
20	38,840	5.08	7.13	—	25,170	22,050	4.18	7.14	5.50	0.00	0.00	
21	37,680	4.24	7.15	—	23,870	21,270	4.06	7.16	5.40	0.00	0.00	
22	38,280	4.08	7.16	—	24,840	21,890	3.89	7.16	5.50	0.00	0.00	
23	39,000	4.48	7.16	—	25,980	22,660	3.97	7.22	5.40	0.00	0.00	
24	37,440	4.71	7.09	—	24,760	21,190	4.41	7.10	5.30	0.00	0.00	
25	37,790	4.75	7.12	—	25,820	21,290	4.22	7.15	5.20	0.00	0.00	
26	37,860	4.50	7.13	—	24,920	21,830	4.18	7.21	5.20	0.00	0.00	
27	38,420	4.48	7.11	—	25,240	22,060	4.72	7.16	5.30	0.00	0.00	
28	37,540	4.24	7.15	—	24,670	21,910	3.75	7.18	5.40	0.00	0.00	
29	38,740	4.37	7.16	—	25,600	22,080	3.89	7.17	5.30	0.00	0.00	
30	38,350	4.22	7.17	—	25,650	22,030	3.78	7.20	5.20	0.00	0.00	
31	38,650	4.41	7.20	—	26,330	21,730	3.93	7.21	5.10	0.00	0.00	
合計	1,170,660	—	—	—	763,050	669,160	—	—	—	0.00	0.00	
最大	39,000	6.18	7.20	—	26,330	22,660	7.20	7.22	7.20	0.00	0.00	
最小	34,950	4.08	7.04	—	23,120	20,310	3.75	7.04	5.10	0.00	0.00	
平均	37,763	5.06	7.11	—	24,615	21,586	4.22	7.14	5.90	0.00	0.00	

## 初野浄水場 流量水質報告書

令和3年2月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	37,240	4.43	7.22	—	24,840	20,970	3.80	7.22	5.00	0.00	0.00	
2	38,060	4.11	7.21	—	25,100	21,930	3.68	7.19	5.10	0.00	0.00	
3	38,050	4.00	7.18	—	25,180	21,490	3.52	7.18	5.00	0.00	0.00	
4	38,420	4.06	7.20	—	25,470	21,740	3.60	7.23	5.00	0.00	0.00	
5	37,540	4.07	7.19	—	24,680	21,110	3.54	7.31	4.80	0.00	0.00	
6	39,730	4.14	7.25	—	26,240	22,840	3.65	7.25	5.00	0.00	0.00	
7	37,230	4.07	7.24	—	24,680	21,360	3.46	7.35	5.10	0.00	0.00	
8	38,310	3.86	7.23	—	25,480	21,380	3.36	7.32	5.10	0.00	0.00	
9	37,630	3.90	7.24	—	25,150	21,450	3.35	7.33	4.90	0.00	0.00	
10	37,980	3.84	7.26	—	25,120	21,600	3.47	7.32	4.80	0.00	0.00	
11	38,500	3.87	7.27	—	25,580	22,300	3.42	7.30	4.80	0.00	0.00	
12	37,700	4.02	7.26	—	25,120	21,520	3.36	7.37	4.80	0.00	0.00	
13	38,530	4.21	7.26	—	25,650	22,010	3.40	7.31	4.80	0.00	0.00	
14	37,370	7.10	7.11	—	22,640	19,410	10.33	7.32	4.90	0.00	0.00	
15	44,520	3.96	7.05	—	21,790	16,050	2.96	7.28	5.20	0.00	0.00	
16	43,070	4.96	7.54	—	24,990	16,680	5.40	7.35	5.50	0.00	0.00	
17	36,690	5.95	7.50	—	20,670	15,900	5.64	7.52	5.10	0.00	0.00	
18	40,130	6.51	7.48	—	21,860	17,400	6.00	7.52	5.00	0.00	0.00	
19	38,840	7.60	7.51	—	23,360	17,750	6.90	7.50	4.90	0.00	0.00	
20	39,800	7.33	7.48	—	23,840	17,770	7.03	7.56	5.00	0.00	0.00	
21	39,250	6.91	7.51	—	24,110	18,050	6.55	7.54	5.20	0.00	0.00	
22	38,970	6.63	7.48	—	23,760	19,490	6.21	7.50	5.30	0.00	0.00	
23	39,970	6.43	7.47	—	24,420	21,920	6.20	7.52	5.70	0.00	0.00	
24	39,640	7.07	7.48	—	24,360	21,470	6.63	7.54	5.40	0.00	0.00	
25	39,060	6.43	7.52	—	23,700	21,040	6.37	7.52	5.20	0.00	0.00	
26	39,900	6.23	7.51	—	24,190	21,540	6.16	7.56	5.20	0.00	0.00	
27	39,190	6.10	7.52	—	23,840	21,380	5.94	7.52	5.10	0.00	0.00	
28	40,080	5.89	7.50	—	24,960	21,560	5.63	7.56	5.10	0.00	0.00	
合計	1,091,400	—	—	—	680,780	569,110	—	—	—	0.00	0.00	
最大	44,520	7.60	7.54	—	26,240	22,840	10.33	7.56	5.70	0.00	0.00	
最小	36,690	3.84	7.05	—	20,670	15,900	2.96	7.18	4.80	0.00	0.00	
平均	38,979	5.27	7.35	—	24,314	20,325	4.98	7.39	5.07	0.00	0.00	

## 初野浄水場 流量水質報告書

令和3年3月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	39,360	6.08	7.49	—	24,500	21,170	5.58	7.52	5.20	0.00	0.00	
2	38,410	5.02	7.51	—	23,720	21,400	4.94	7.50	5.70	0.00	0.00	
3	39,380	5.08	7.55	—	24,650	21,520	4.73	7.53	5.80	0.00	0.00	
4	38,510	5.25	7.49	—	24,820	20,970	5.13	7.54	5.50	0.00	0.00	
5	40,010	5.50	7.49	—	25,540	22,020	5.29	7.53	5.55	0.00	0.00	
6	39,340	4.71	7.53	—	24,440	21,490	4.57	7.52	5.70	0.00	0.00	
7	38,700	4.53	7.51	—	24,690	21,610	4.40	7.55	5.80	0.00	0.00	
8	39,970	4.77	7.51	—	26,200	21,120	4.51	7.54	5.50	0.00	0.00	
9	40,000	4.56	7.51	—	25,710	22,390	4.39	7.55	5.50	0.00	0.00	
10	37,060	4.31	7.50	—	23,250	20,540	4.10	7.56	5.30	0.00	0.00	
11	37,800	4.40	7.54	—	23,800	21,300	3.96	7.53	5.90	0.00	0.00	
12	38,620	4.63	7.52	—	24,310	21,260	4.09	7.56	5.90	0.00	0.00	
13	39,330	4.43	7.45	—	25,240	21,870	3.96	7.57	5.90	0.00	0.00	
14	37,710	8.21	7.71	—	24,780	20,430	4.26	7.54	6.10	0.00	0.00	
15	38,050	4.19	7.53	—	24,800	21,180	4.10	7.54	6.40	0.00	0.00	
16	38,360	4.05	7.52	—	24,540	21,800	3.74	7.52	6.40	0.00	0.00	
17	38,140	3.71	7.50	—	24,200	21,410	3.65	7.50	6.40	0.00	0.00	
18	37,090	4.96	7.47	—	23,310	21,440	4.11	7.53	6.50	0.00	0.00	
19	39,050	5.09	7.49	—	25,330	22,210	4.72	7.52	6.70	0.00	0.00	
20	38,140	4.86	7.48	—	23,820	21,370	4.66	7.51	6.60	0.00	0.00	
21	38,560	4.62	7.47	—	24,870	21,090	4.61	7.47	6.60	0.00	0.00	
22	38,650	4.45	7.55	—	24,910	20,990	4.03	7.55	7.00	0.00	0.00	
23	38,570	5.04	7.50	—	24,810	21,050	4.63	7.52	7.10	0.00	0.00	
24	40,350	5.29	7.47	—	26,040	21,430	4.99	7.48	7.10	0.00	0.00	
25	37,770	4.67	7.48	—	24,060	20,140	4.44	7.52	7.40	0.00	0.00	
26	39,040	4.56	7.52	—	25,190	21,100	4.30	7.56	7.40	0.00	0.00	
27	38,310	4.63	7.55	—	24,590	21,430	4.24	7.60	8.00	0.00	0.00	
28	38,730	4.48	7.49	—	24,840	20,370	4.32	7.50	7.60	0.00	0.00	
29	38,600	4.39	7.51	—	25,710	20,350	4.12	7.52	8.10	0.00	0.00	
30	38,010	4.29	7.55	—	24,310	20,400	4.02	7.53	8.80	0.00	0.00	
31	39,120	4.38	7.54	—	25,550	20,930	4.01	7.52	8.80	0.00	0.00	
合計	1,198,740	—	—	—	766,530	657,780	—	—	—	0.00	0.00	
最大	40,350	8.21	7.71	—	26,200	22,390	5.58	7.60	8.80	0.00	0.00	
最小	37,060	3.71	7.45	—	23,250	20,140	3.65	7.47	5.20	0.00	0.00	
平均	38,669	4.81	7.51	—	24,727	21,219	4.41	7.53	6.52	0.00	0.00	