

(4) 第一 (発) 沖合2km

採取日	核種濃度 (Bq/L ※PuはmBq/L)									備考
	全β放射能	¹³⁴ Cs	¹³⁷ Cs	³ H			⁹⁰ Sr	²³⁸ Pu	²³⁹⁺²⁴⁰ Pu	
				減圧蒸留法	迅速分析	電解濃縮法				
H1. 6. 14	ND	ND	ND	0.94						
H1. 10. 24	0.04	ND	ND	0.50						
H2. 7. 3	ND	ND	ND	ND						
H2. 10. 2	ND	ND	ND	1.3						
H3. 6. 20	ND	ND	ND	ND						
H3. 11. 7	ND	ND	ND	ND						
H4. 6. 26	ND	ND	ND	ND						
H4. 10. 29	ND	ND	ND	0.95						
H5. 6. 25	0.01	ND	ND	ND						
H5. 10. 22	0.01	ND	ND	1.0						
H6. 6. 7	ND	ND	0.003	ND						
H6. 11. 5	0.01	ND	0.002	ND						
H7. 6. 6	0.01	ND	0.002	ND						
H7. 10. 4	0.01	ND	0.002	ND						
H8. 6. 6	ND	ND	0.002	1.2			0.003			
H8. 10. 4	0.01	ND	0.003	ND						
H9. 6. 5	ND	ND	0.002	ND			0.002			
H9. 10. 9	0.01	ND	0.002	0.76						
H10. 6. 5	0.02	ND	0.002	ND			0.002			
H10. 10. 13	ND	ND	0.001	0.43						
H11. 5. 26	ND	ND	0.003	ND			0.001			
H11. 10. 12	0.01	ND	0.002	ND						
H12. 5. 30	ND	ND	ND	0.43			0.002			
H12. 10. 10	ND	ND	ND	ND						
H13. 5. 18	ND	ND	ND	ND			0.001		0.008	
H13. 10. 16	0.02	ND	ND	0.57						
H14. 5. 20	ND	ND	ND	ND			0.002		ND	
H14. 10. 25	0.03	ND	ND	ND						
H15. 5. 21	ND	ND	ND	ND			0.002		ND	
H15. 10. 20	ND	ND	0.002	ND						
H16. 5. 19	0.02	ND	ND	ND			0.002		ND	
H16. 10. 28	0.02	ND	ND	0.67						
H17. 5. 23	ND	ND	ND	ND			0.001		0.009	
H17. 10. 26	ND	ND	0.001	ND						
H18. 5. 17	0.01	ND	ND	ND			0.002		0.009	
H18. 10. 12	0.02	ND	0.002	ND						
H19. 5. 16	0.02	ND	ND	ND			ND		ND	
H19. 10. 10	0.01	ND	0.002	ND						
H20. 5. 16	0.01	ND	ND	ND			0.001		ND	
H20. 10. 17	0.01	ND	0.002	ND						
H21. 5. 15	0.01	ND	ND	ND			0.001		0.008	
H21. 10. 13	ND	ND	ND	ND						
H22. 5. 21	ND	ND	0.002	ND			0.001		ND	
H22. 10. 7	0.01	ND	0.001	ND						
H23. 4. 1	欠測	欠測	欠測	欠測			欠測		欠測	
H23. 10. 1	欠測	欠測	欠測	欠測						
H25. 7. 31	0.02	ND	0.058	ND			0.002	ND	ND	
H25. 8. 19	0.14	ND	0.082	0.53			0.26	ND	ND	
H25. 9. 19	0.04	ND	ND	ND			0.002	ND	ND	
H25. 10. 5	0.02	ND	ND	0.35			0.014	ND	ND	
H25. 10. 30	0.03	ND	0.12	0.58			0.028	ND	ND	
H25. 11. 12	0.02	ND	ND	ND			0.002	ND	ND	
H25. 12. 9	ND	ND	ND	ND			0.002	ND	ND	
H26. 1. 14	0.04	ND	ND	ND			0.007	ND	ND	

(4) 第一 (発) 沖合2km

採取日	核種濃度 (Bq/L ※PuはmBq/L)									備考
	全β放射能	¹³⁴ Cs	¹³⁷ Cs	³ H			⁹⁰ Sr	²³⁸ Pu	²³⁹⁺²⁴⁰ Pu	
				減圧蒸留法	迅速分析	電解濃縮法				
H26. 2. 3	0.04	ND	0.088	ND			0.014	ND	ND	
H26. 3. 10	0.03	ND	ND	ND			0.018	ND	0.009	
H26. 4. 14	0.03	ND	ND	ND			0.002	ND	ND	
H26. 5. 12	0.03	ND	ND	ND			0.004	ND	ND	
H26. 6. 16	0.03	ND	ND	ND			0.004	ND	0.006	
H26. 7. 7	0.04	ND	ND	ND			0.004	ND	ND	
H26. 8. 20	0.03	ND	ND	0.43			0.002	ND	ND	
H26. 9. 16	0.03	ND	0.058	ND			0.005	ND	ND	
H26. 10. 20	0.03	ND	0.092	ND			0.016	ND	ND	
H26. 11. 10	0.03	ND	ND	ND			0.005	ND	ND	
H26. 12. 8	0.04	ND	0.13	ND			0.007	ND	ND	
H27. 1. 14	0.04	ND	ND	ND			0.005	ND	0.009	
H27. 2. 10	0.04	ND	ND	ND			0.001	ND	ND	
H27. 3. 3	0.03	ND	ND	0.48			0.002	ND	ND	
H27. 4. 22	0.02	ND	ND	ND			0.001	ND	0.009	
H27. 5. 18	0.03	ND	0.054	ND			0.005	ND	ND	
H27. 6. 16	0.02	ND	ND	ND			0.002	ND	ND	
H27. 7. 21	0.02	ND	0.054	ND			0.002	ND	ND	
H27. 8. 17	0.02	ND	ND	ND			0.001	ND	ND	
H27. 9. 14	0.02	ND	0.052	ND			0.002	ND	ND	
H27. 10. 13	0.02	ND	ND	ND			0.001	ND	ND	
H27. 11. 17	0.04	ND	ND	ND			0.004	ND	ND	
H27. 12. 14	0.04	ND	ND	ND			0.002	ND	0.008	
H28. 1. 22	0.04	ND	ND	ND			0.003	ND	0.008	
H28. 2. 8	0.03	ND	ND	0.54			0.002	ND	ND	
H28. 3. 3	ND	ND	ND	ND			0.001	ND	ND	
H28. 4. 20	0.02	0.003	0.011	0.38			0.0013	ND	ND	
H28. 5. 16	0.02	ND	0.007	ND			0.0009	ND	ND	
H28. 6. 15	0.03	ND	0.012	ND			0.0008	ND	ND	
H28. 7. 11	0.02	ND	0.006	ND			0.0006	ND	ND	
H28. 8. 3	0.02	0.001	0.006	ND			0.0011	ND	ND	
H28. 9. 15	0.02	0.003	0.026	ND			0.0019	ND	ND	
H28. 10. 18	0.02	0.003	0.015	ND			0.0011	ND	ND	
H28. 11. 15	0.02	0.008	0.05	ND			0.0019	ND	ND	
H28. 12. 12	0.04	ND	0.009	ND			0.0027	ND	ND	
H29. 1. 20	0.03	ND	0.007	ND			0.0035	ND	ND	
H29. 2. 14	0.03	ND	0.015	ND			0.001	ND	ND	
H29. 3. 7	0.03	ND	0.01	ND			0.0012	ND	ND	
H29. 4. 20	0.04	ND	0.009	ND			0.0009	ND	ND	
H29. 5. 16	0.04	0.005	0.037	ND			0.0009	ND	ND	
H29. 6. 13	0.03	ND	0.005	ND			0.0011	ND	ND	
H29. 7. 10	0.03	ND	0.01	ND			0.0011	ND	0.006	
H29. 8. 18	0.02	ND	0.004	ND			0.0011	ND	ND	
H29. 9. 14	0.02	ND	0.009	ND			0.0012	ND	ND	
H29. 10. 17	0.02	ND	0.008	ND			0.0009	ND	ND	
H29. 11. 14	0.03	ND	0.007	ND			0.0016	ND	0.006	
H29. 12. 5	0.02	ND	0.007	ND			0.0012	ND	ND	
H30. 1. 16	0.03	ND	0.007	ND			0.0015	ND	ND	
H30. 2. 13	0.02	ND	0.003	ND			0.0013	ND	ND	
H30. 3. 13	0.02	ND	0.016	ND			0.002	ND	0.008	
H30. 4. 20	ND	ND	0.008	ND			0.0006	ND	ND	
H30. 5. 16	0.03	ND	0.019	ND			0.0015	ND	0.007	
H30. 6. 14	0.02	ND	0.011	ND			0.0007	ND	ND	
H30. 7. 10	0.02	ND	0.004	ND			0.0011	ND	0.007	

(4) 第一 (発) 沖合2km

採取日	核種濃度 (Bq/L ※PuはmBq/L)									備考
	全β放射能	¹³⁴ Cs	¹³⁷ Cs	³ H			⁹⁰ Sr	²³⁸ Pu	²³⁹⁺²⁴⁰ Pu	
				減圧蒸留法	迅速分析	電解濃縮法				
H30. 8. 19	0.03	ND	0.007	ND			0.001	ND	ND	
H30. 9. 13	ND	ND	0.012	ND			0.0009	ND	ND	
H30. 10. 5	0.02	ND	0.009	ND			0.0006	ND	ND	
H30. 11. 14	ND	ND	0.007	ND			0.0012	ND	0.004	
H30. 12. 11	0.02	ND	0.007	ND			0.0007	ND	ND	
H31. 1. 17	0.02	ND	0.009	ND			0.0006	ND	0.005	
H31. 2. 13	0.03	ND	0.004	ND			0.001	ND	0.004	
H31. 3. 14	0.02	ND	0.009	ND			0.0008	ND	ND	
H31. 4. 17	0.02	ND	0.006	ND			0.0006	ND	0.006	
R1. 5. 10	0.02	ND	0.005	ND			0.0008	ND	ND	
R1. 6. 4	0.02	ND	0.006	ND			ND	ND	ND	
R1. 7. 2	0.02	ND	0.024	ND			0.0019	ND	ND	
R1. 8. 1	0.02	ND	0.009	ND			0.0005	ND	ND	
R1. 9. 20	0.02	ND	0.004	ND			0.0010	ND	ND	
R1. 10. 2	0.03	ND	0.002	ND			0.0014	ND	ND	
R1. 11. 21	0.02	ND	0.012	ND			0.0006	ND	ND	
R1. 12. 11	0.03	ND	0.008	ND			0.0008	ND	ND	
R2. 1. 8	0.03	ND	0.023	ND			0.0005	ND	0.008	
R2. 2. 4	0.03	ND	0.03	ND			0.0009	ND	ND	
R2. 3. 12	0.02	ND	0.014	ND			0.0011	ND	ND	
R2. 4. 22	0.02	ND	0.022	ND			0.0011	ND	ND	
R2. 5. 14	0.02	ND	0.005	ND			0.0008	ND	ND	
R2. 6. 2	0.02	ND	0.004	ND			0.0007	ND	0.010	
R2. 7. 3	0.02	ND	0.004	ND			0.0006	ND	0.011	
R2. 8. 6	0.02	ND	0.011	ND			0.0007	ND	ND	
R2. 9. 11	0.02	ND	0.002	ND			0.0008	ND	ND	
R2. 10. 20	0.02	ND	0.004	ND			0.0006	ND	ND	
R2. 11. 12	0.03	ND	0.003	ND			0.0009	ND	ND	
R2. 12. 4	0.02	ND	0.006	ND			0.0005	ND	ND	
R3. 1. 7	0.02	ND	0.006	ND			0.0009	ND	ND	
R3. 2. 12	0.04	ND	0.002	ND			0.0006	ND	ND	
R3. 3. 4	0.02	ND	0.015	ND			0.0009	ND	ND	
R3. 4. 20	0.02	ND	0.01	ND			0.0007	ND	0.011	
R3. 5. 12	0.02	ND	0.004	ND			0.0007	ND	ND	
R3. 6. 3	0.02	ND	0.011	ND			0.0010	ND	0.008	
R3. 7. 6	0.01	ND	0.008	ND			0.0011	ND	ND	
R3. 8. 4	0.02	ND	0.008	ND			0.0006	ND	ND	
R3. 9. 2	0.01	ND	0.006	ND			0.0008	ND	ND	
R3. 10. 15	0.02	ND	0.016	ND			0.0011	ND	ND	
R3. 11. 4	0.02	ND	0.005	ND			0.0009	ND	ND	
R3. 12. 14	0.02	ND	0.012	ND			0.0009	ND	0.007	
R4. 1. 13	0.02	ND	0.003	ND			0.0006	ND	0.006	
R4. 2. 3	0.02	ND	0.006	ND			ND	ND	ND	
R4. 3. 3	0.02	ND	0.009	ND			0.0009	ND	0.008	
R4. 4. 13	0.01	ND	0.017	ND			0.0009	ND	ND	
R4. 5. 19	0.01	ND	0.011	ND		0.09	0.0008	ND	ND	
R4. 6. 19	0.01	ND	0.008	ND			ND	ND	ND	
R4. 7. 5	0.01	ND	0.012	ND			0.0007	ND	ND	
R4. 8. 2	0.01	ND	0.004	ND		0.08	0.0008	ND	ND	
R4. 9. 13	0.01	ND	0.004	ND			0.0007	ND	ND	
R4. 10. 21	0.02	ND	0.007	ND			0.0011	ND	ND	
R4. 11. 8	0.01	ND	0.007	ND		0.05	0.0009	ND	ND	
R4. 12. 9	0.05	ND	0.003	ND			0.0012	ND	ND	
R5. 1. 13	0.05	ND	0.003	ND			0.0009	ND	ND	

(4) 第一 (発) 沖合2km

採取日	核種濃度 (Bq/L ※PuはmBq/L)									備考
	全β放射能	¹³⁴ Cs	¹³⁷ Cs	³ H			⁹⁰ Sr	²³⁸ Pu	²³⁹⁺²⁴⁰ Pu	
				減圧蒸留法	迅速分析	電解濃縮法				
R5. 2. 7	0.07	ND	0.003	ND		0.06	0.0008	ND	0.008	
R5. 3. 7	0.02	ND	0.002	ND			0.0005	ND	ND	
R5. 4. 25	0.02	ND	0.004	ND			0.0009	ND	0.010	
R5. 5. 10	0.01	ND	0.010	ND		ND	0.0009	ND	0.012	
R5. 6. 7	0.02	ND	0.025	ND			0.0016	ND	ND	
R5. 7. 11	0.01	ND	0.006	ND			0.0008	ND	ND	
R5. 8. 8	0.02	ND	0.004	ND		ND	ND	ND	ND	
R5. 8. 25					ND					
R5. 8. 30					ND					
R5. 9. 3	0.01	ND	0.004		ND	0.15	0.0006	ND	ND	
R5. 9. 12					ND					
R5. 9. 19					ND					
R5. 9. 26					ND					
R5. 10. 8					ND					
R5. 10. 12	0.02	ND	0.008		ND	0.05	0.0008	ND	ND	
R5. 10. 20					ND					
R5. 10. 24					ND					
R5. 11. 3					ND					
R5. 11. 9	0.02	ND	0.008		ND	0.17	0.0006	ND	0.007	
R5. 11. 14					ND					
R5. 11. 22					ND					
R5. 11. 28					ND					
R5. 12. 5	0.02	ND	0.006		ND	0.07	0.0010	ND	ND	
R5. 12. 15					ND					
R5. 12. 20					ND					
R6. 1. 10					ND					
R6. 1. 18	0.02	ND	0.003		ND	0.06	0.0006	ND	ND	
R6. 1. 31					ND					
R6. 2. 9	分析中	分析中	分析中		ND	分析中	分析中	分析中	分析中	
R6. 2. 15					ND					
R6. 3. 15	分析中	分析中	分析中		ND	分析中	分析中	分析中	分析中	