

採水日	調査地点									検出下限値
	第一(発)南放水口付近	第一(発)北放水口付近	第一(発)取水口付近	第一(発)沖合2km	夫沢・熊川沖2km	双葉・前田川沖2km	ALPS処理水放水口北2km西0.5km	ALPS処理水放水口北1km	ALPS処理水放水口南1km	
R6.9.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8~4.0
R6.10.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8~4.3
R6.10.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.9~4.3
R6.10.16	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.5~4.0
R6.10.22	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8~4.1
R6.11.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.1~4.2
R6.11.14	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.0~4.3
R6.12.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8~4.2
R7.1.24	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8~4.5
R7.2.21	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.6~3.8
R7.3.11	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.5~4.1
R7.3.21	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.0~4.5
R7.3.25	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8~4.2
R7.4.11	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8~4.0
R7.4.18	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.7~4.4
R7.4.22	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8~4.2
R7.5.21	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.1~4.5
R7.6.12	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8~4.0
R7.7.25	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.6~4.1
R7.7.29	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.4~5.1
R7.8.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8~4.1
R7.8.15	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.2~4.6
R7.8.19	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.1~4.3
R7.9.16	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.9~4.1
R7.10.22	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.9~4.3
R7.10.31	ND	ND	ND	ND	ND	ND	ND	5.5	ND	3.9~4.3
R7.11.14	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.0~5.8
R7.11.20	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.4~5.0
R7.12.17	ND	ND	ND	ND	ND	ND	ND	5.5	ND	3.7~4.1
R8.1.23	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.9~4.3
R8.2.10	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.7~3.9
R8.3.9	4.6	ND	ND	ND	ND	ND	ND	ND	ND	3.8~4.0
R8.3.18	ND	ND	ND	ND	ND	ND	ND	ND	5.0	4.1~4.6
R8.4.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.3
R8.4.15	4.3	ND	ND	ND	ND	ND	ND	ND	ND	3.9

■:ALPS処理水放出期間中の採水

※1: 令和5年度4回目の放出については令和6年2月28日から開始されたが、令和6年3月15日0時14分頃発生した地震の影響により同日15時49分まで放出を停止していた。