

初野浄水場 流量水質報告書

令和7年4月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	36,140	2.26	7.56	—	22,820	19,300	1.61	7.53	7.70	0.00	0.00	
2	36,820	2.33	7.55	—	23,400	19,220	1.56	7.62	7.60	0.00	0.00	
3	35,270	4.21	7.47	—	22,590	18,770	3.46	7.53	7.60	0.00	0.00	
4	35,590	3.39	7.48	—	22,300	18,980	2.27	7.48	7.50	0.00	0.00	
5	35,180	2.60	7.51	—	21,960	18,890	1.73	7.52	8.00	0.00	0.00	
6	35,590	2.58	7.49	—	22,260	18,670	1.72	7.50	8.00	0.00	0.00	
7	35,170	2.35	7.52	—	22,140	17,560	1.71	7.55	8.40	0.00	0.00	
8	35,350	3.70	7.53	—	21,830	15,410	2.14	7.56	9.10	0.00	0.00	
9	33,630	2.70	7.52	—	19,950	15,270	2.13	7.49	8.90	0.00	0.00	
10	34,030	2.93	7.56	—	20,490	15,590	2.11	7.58	9.40	0.00	0.00	
11	33,880	2.60	7.53	—	19,910	15,530	1.90	7.58	9.30	0.00	0.00	
12	33,460	2.76	7.54	—	19,890	15,360	2.13	7.55	9.10	0.00	0.00	
13	33,810	2.41	7.54	—	20,700	14,880	1.96	7.52	9.20	0.00	0.00	
14	32,990	2.28	7.50	—	20,360	14,740	2.02	7.49	9.20	0.00	0.00	
15	34,150	2.28	7.58	—	20,340	16,250	1.81	7.62	10.00	0.00	0.00	
16	33,570	2.04	7.61	—	19,860	16,140	1.72	7.56	9.90	0.00	0.00	
17	33,700	1.98	7.59	—	19,950	15,820	1.55	7.59	10.10	0.00	0.00	
18	33,690	1.87	7.54	—	19,440	15,560	1.54	7.54	10.60	0.00	0.00	
19	33,290	1.79	7.55	—	19,240	15,610	1.48	7.51	10.40	0.00	0.00	
20	33,710	1.74	7.53	—	19,740	14,950	1.34	7.51	11.10	0.00	0.00	
21	33,300	1.67	7.51	—	19,630	14,880	1.25	7.52	11.20	0.00	0.00	
22	33,540	1.56	7.47	—	19,350	15,410	1.20	7.58	11.60	0.00	0.00	
23	33,520	1.46	7.49	—	19,380	15,290	1.18	7.52	11.40	0.00	0.00	
24	34,150	1.55	7.52	—	20,560	15,890	1.15	7.49	11.50	0.00	0.00	
25	32,910	1.54	7.51	—	19,060	15,220	1.11	7.49	11.40	0.00	0.00	
26	33,960	1.61	7.54	—	20,060	15,370	1.04	7.57	11.80	0.00	0.00	
27	33,350	1.47	7.52	—	19,490	14,710	1.02	7.52	11.80	0.00	0.00	
28	33,400	1.40	7.50	—	19,530	15,100	1.02	7.53	12.10	0.00	0.00	
29	33,770	1.50	7.58	—	20,210	14,430	1.10	7.56	12.00	0.00	0.00	
30	32,910	1.65	7.58	—	19,550	14,770	1.20	7.58	12.90	0.00	0.00	
合計	1,023,830			—	615,990	483,570				0.00	0.00	
最大	36,820	4.21	7.61	—	23,400	19,300	3.46	7.62	12.90	0.00	0.00	
最小	32,910	1.40	7.47	—	19,060	14,430	1.02	7.48	7.50	0.00	0.00	
平均	34,128	2.21	7.53	—	20,533	16,119	1.64	7.54	9.96	0.00	0.00	

初野浄水場 流量水質報告書

令和7年5月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	32,570	1.55	7.57	—	18,930	15,060	1.20	7.55	12.80	0.00	0.00	
2	35,790	1.67	7.58	—	21,830	15,060	1.36	7.59	12.60	0.00	0.00	
3	35,750	2.02	7.52	—	22,230	14,830	1.24	7.54	12.60	0.00	0.00	
4	35,530	1.77	7.54	—	22,100	14,060	1.38	7.52	13.10	0.00	0.00	
5	35,900	1.83	7.57	—	22,390	14,470	1.32	7.55	13.30	0.00	0.00	
6	35,660	1.85	7.56	—	22,200	14,390	1.44	7.54	13.20	0.00	0.00	
7	35,990	1.71	7.56	—	22,630	14,610	1.34	7.52	13.00	0.00	0.00	
8	32,190	1.76	7.55	—	18,580	14,960	1.27	7.56	13.30	0.00	0.00	
9	32,230	1.70	7.56	—	17,910	14,880	1.53	7.55	13.30	0.00	0.00	
10	32,680	1.77	7.58	—	18,820	15,100	1.24	7.56	13.40	0.00	0.00	
11	32,820	1.67	7.63	—	19,480	14,830	1.29	7.65	13.50	0.00	0.00	
12	32,990	1.71	7.60	—	19,340	15,190	1.28	7.56	13.70	0.00	0.00	
13	32,620	1.77	7.54	—	18,980	15,210	1.33	7.55	13.70	0.00	0.00	
14	32,030	1.80	7.56	—	17,900	15,090	1.30	7.54	13.90	0.00	0.00	
15	32,810	1.77	7.55	—	18,270	15,390	1.32	7.59	14.00	0.00	0.00	
16	33,340	1.81	7.53	—	18,790	15,330	1.42	7.55	14.40	0.00	0.00	
17	31,980	1.93	7.52	—	17,530	15,040	1.48	7.51	14.50	0.00	0.00	
18	32,430	2.07	7.55	—	19,420	14,430	1.54	7.54	14.80	0.00	0.00	
19	32,610	2.10	7.52	—	18,510	14,540	1.62	7.48	15.10	0.00	0.00	
20	33,190	2.15	7.54	—	18,490	15,760	1.61	7.56	14.90	0.00	0.00	
21	32,260	2.22	7.53	—	17,910	15,280	1.59	7.52	15.50	0.00	0.00	
22	32,550	2.36	7.56	—	17,630	15,310	1.69	7.51	15.10	0.00	0.00	
23	33,290	2.39	7.60	—	18,670	15,210	1.70	7.57	15.30	0.00	0.00	
24	31,890	2.43	7.72	—	18,090	14,650	1.88	7.56	15.20	0.00	0.00	
25	32,530	2.23	7.67	—	19,100	15,100	1.96	7.58	15.10	0.00	0.00	
26	32,590	2.26	7.70	—	19,200	14,330	2.17	7.64	15.00	0.00	0.00	
27	32,450	2.20	7.64	—	18,350	15,190	2.10	7.64	15.00	0.00	0.00	
28	32,550	2.20	7.66	—	18,300	14,840	1.91	7.57	14.80	0.00	0.00	
29	32,680	2.09	7.75	—	18,210	15,230	1.92	7.59	15.00	0.00	0.00	
30	32,320	1.93	7.72	—	17,810	14,790	1.78	7.60	15.10	0.00	0.00	
31	34,080	1.87	7.68	—	20,550	15,610	1.96	7.54	15.00	0.00	0.00	
合計	1,030,300			—	598,150	463,770				0.00	0.00	
最大	35,990	2.43	7.75	—	22,630	15,760	2.17	7.65	15.50	0.00	0.00	
最小	31,890	1.55	7.52	—	17,530	14,060	1.20	7.48	12.60	0.00	0.00	
平均	33,235	1.95	7.59	—	19,295	14,960	1.55	7.56	14.17	0.00	0.00	

初野浄水場 流量水質報告書

令和7年6月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	34,890	2.24	7.60	—	21,640	14,560	2.29	7.52	14.80	0.00	0.00	
2	34,670	2.28	7.55	—	21,410	14,160	2.08	7.44	14.70	0.00	0.00	
3	35,350	2.26	7.56	—	20,640	15,510	2.05	7.46	15.30	0.00	0.00	
4	33,980	2.76	7.60	—	20,200	15,010	2.32	7.45	15.50	0.00	0.00	
5	34,020	2.39	7.50	—	19,750	15,220	2.35	7.50	15.60	0.00	0.00	
6	32,390	2.35	7.66	—	17,710	14,980	2.29	7.64	16.20	0.00	0.00	
7	33,120	2.18	7.78	—	18,290	15,250	2.39	7.54	16.00	0.00	0.00	
8	33,320	2.16	7.73	—	19,430	14,710	2.15	7.56	16.20	0.00	0.00	
9	32,700	2.09	7.73	—	19,060	14,450	2.02	7.54	16.40	0.00	0.00	
10	34,180	1.36	7.34	—	19,140	15,760	1.24	7.33	14.10	0.00	0.00	
11	32,260	1.30	7.30	—	18,500	15,010	1.22	7.24	13.80	0.00	0.00	
12	33,100	1.42	7.53	—	19,150	15,370	1.36	7.42	15.20	0.00	0.00	
13	33,740	1.32	7.52	—	18,800	15,600	1.27	7.49	15.80	0.00	0.00	
14	32,990	1.23	7.33	—	18,300	15,410	1.14	7.30	14.30	0.00	0.00	
15	33,210	1.24	7.30	—	19,940	14,820	1.23	7.31	14.20	0.00	0.00	
16	32,970	1.30	7.27	—	19,590	16,500	1.28	7.26	14.40	0.00	0.00	
17	35,880	1.33	7.21	—	21,530	18,670	1.40	7.27	14.40	0.00	0.00	
18	37,460	1.25	7.18	—	21,910	20,380	1.13	7.22	14.30	0.00	0.00	
19	37,240	1.20	7.13	—	22,410	20,130	1.17	7.20	14.20	0.00	0.00	
20	38,150	1.20	7.13	—	22,590	20,250	1.18	7.22	14.20	0.00	0.00	
21	36,930	1.20	7.14	—	21,990	19,270	1.15	7.19	14.20	0.00	0.00	
22	37,350	1.17	7.11	—	23,140	19,040	1.04	7.17	14.10	0.00	0.00	
23	36,790	1.13	7.10	—	22,950	18,890	1.09	7.14	13.90	0.00	0.00	
24	36,940	1.14	7.10	—	22,670	19,310	1.04	7.09	13.80	0.00	0.00	
25	38,140	1.12	7.10	—	23,810	19,780	1.08	7.14	14.10	0.00	0.00	
26	37,270	1.12	7.09	—	22,610	19,520	0.98	7.11	14.20	0.00	0.00	
27	38,980	1.10	7.10	—	22,740	19,310	1.03	7.15	14.20	0.00	0.00	
28	38,530	1.03	7.11	—	22,970	20,190	0.97	7.14	14.40	0.00	0.00	
29	38,370	1.06	7.10	—	25,360	19,120	1.03	7.18	14.50	0.00	0.00	
30	38,350	1.00	7.08	—	24,220	19,120	1.00	7.12	14.60	0.00	0.00	
合計	1,063,270			—	632,450	515,300				0.00	0.00	
最大	38,980	2.76	7.78	—	25,360	20,380	2.39	7.64	16.40	0.00	0.00	
最小	32,260	1.00	7.08	—	17,710	14,160	0.97	7.09	13.80	0.00	0.00	
平均	35,442	1.53	7.33	—	21,082	17,177	1.47	7.31	14.72	0.00	0.00	

初野浄水場 流量水質報告書

令和7年7月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	38,400	1.02	7.06	—	23,570	19,920	0.88	7.09	14.50	0.00	0.00	
2	38,040	1.00	7.05	—	23,450	19,830	1.29	7.09	14.40	0.00	0.00	
3	38,150	0.98	7.05	—	23,200	20,060	0.96	7.09	14.40	0.00	0.00	
4	39,730	1.02	7.04	—	25,490	20,010	0.93	7.17	15.30	0.00	0.00	
5	38,600	0.96	7.04	—	23,980	20,200	0.82	7.06	14.20	0.00	0.00	
6	39,190	0.93	7.03	—	25,200	19,820	0.80	7.04	14.40	0.00	0.00	
7	37,950	0.92	7.04	—	24,250	19,080	0.77	7.04	14.30	0.00	0.00	
8	38,840	0.90	7.03	—	23,850	20,330	0.79	7.03	14.40	0.00	0.00	
9	39,910	0.85	7.02	—	24,580	20,930	0.76	7.03	14.50	0.00	0.00	
10	39,820	0.94	6.99	—	23,480	20,210	0.92	7.03	14.30	0.00	0.00	
11	40,740	1.09	6.99	—	26,250	19,830	0.90	7.01	14.40	0.00	0.00	
12	37,580	0.99	7.04	—	23,670	19,860	1.06	7.01	14.60	0.00	0.00	
13	37,970	1.09	7.04	—	24,460	19,180	0.90	7.06	14.80	0.00	0.00	
14	37,800	1.37	7.04	—	24,240	19,080	0.87	7.07	14.90	0.00	0.00	
15	37,490	1.42	7.05	—	23,720	19,810	0.83	7.05	14.90	0.00	0.00	
16	38,460	2.20	7.02	—	24,200	20,420	0.82	7.05	15.00	0.00	0.00	
17	38,280	1.01	7.03	—	23,670	20,320	0.79	7.02	15.00	0.00	0.00	
18	37,240	0.97	7.02	—	22,980	19,750	0.81	7.03	14.90	0.00	0.00	
19	38,070	1.05	7.09	—	23,440	20,530	0.96	7.12	17.40	0.00	0.00	
20	37,900	1.01	7.07	—	23,480	19,510	0.79	7.12	17.80	0.00	0.00	
21	37,620	0.92	7.06	—	23,600	19,280	0.70	7.09	17.80	0.00	0.00	
22	37,190	0.85	7.05	—	22,760	19,800	0.65	7.10	17.90	0.00	0.00	
23	38,450	0.85	7.03	—	23,350	20,690	0.63	7.08	18.00	0.00	0.00	
24	37,280	0.86	7.02	—	22,470	20,050	0.61	7.08	18.00	0.00	0.00	
25	38,960	0.87	7.01	—	24,000	20,520	0.67	7.05	18.00	0.00	0.00	
26	39,420	0.85	7.00	—	24,640	19,760	0.70	7.05	18.00	0.00	0.00	
27	39,000	0.89	7.01	—	24,970	19,150	0.68	7.02	17.90	0.00	0.00	
28	39,100	0.84	7.00	—	25,310	19,060	0.67	7.05	17.90	0.00	0.00	
29	39,180	1.01	7.01	—	24,600	20,100	0.68	7.05	18.20	0.00	0.00	
30	38,310	0.85	7.02	—	23,830	19,850	1.10	7.08	18.10	0.00	0.00	
31	38,210	0.86	7.02	—	23,560	19,570	0.69	7.07	18.20	0.00	0.00	
合計	1,192,880			—	744,250	616,510				0.00	0.00	
最大	40,740	2.20	7.09	—	26,250	20,930	1.29	7.17	18.20	0.00	0.00	
最小	37,190	0.84	6.99	—	22,470	19,060	0.61	7.01	14.20	0.00	0.00	
平均	38,480	1.01	7.03	—	24,008	19,887	0.82	7.06	16.01	0.00	0.00	

初野浄水場 流量水質報告書

令和7年8月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	39,000	0.90	7.00	—	24,550	19,740	0.83	7.01	18.10	0.00	0.00	
2	38,650	0.96	6.94	—	24,870	18,640	0.68	7.03	18.20	0.00	0.00	
3	36,640	0.96	7.00	—	23,400	19,520	0.89	7.02	18.30	0.00	0.00	
4	38,400	0.88	6.99	—	23,360	19,350	0.79	7.03	18.30	0.00	0.00	
5	36,130	0.87	7.01	—	21,970	19,480	0.77	7.01	18.40	0.00	0.00	
6	40,350	0.94	7.00	—	23,080	20,930	0.79	6.98	18.30	0.00	0.00	
7	38,720	0.91	7.02	—	24,710	5,440	0.79	7.04	18.40	0.00	0.00	
8	39,260	0.90	7.03	—	24,740	18,180	0.79	7.07	18.40	0.00	0.00	
9	39,760	0.95	7.03	—	24,670	18,920	0.84	7.06	18.40	0.00	0.00	
10	40,250	0.93	7.02	—	25,910	18,060	0.90	7.08	18.40	0.00	0.00	
11	39,650	0.93	6.99	—	26,210	17,470	0.78	6.99	18.40	0.00	0.00	
12	39,670	0.94	6.98	—	25,510	18,110	0.79	7.03	18.40	0.00	0.00	
13	39,140	1.19	6.98	—	25,020	18,100	1.02	7.03	18.50	0.00	0.00	
14	38,550	1.06	7.00	—	23,920	17,510	0.93	7.04	18.50	0.00	0.00	
15	38,720	1.00	7.02	—	24,010	17,670	0.91	7.04	18.70	0.00	0.00	
16	38,030	1.14	7.01	—	23,810	17,450	0.91	7.08	18.70	0.00	0.00	
17	38,630	1.04	7.03	—	24,580	17,480	0.96	7.06	18.70	0.00	0.00	
18	39,440	1.07	7.00	—	24,620	18,740	0.97	7.05	18.70	0.00	0.00	
19	36,900	1.03	7.03	—	23,190	18,340	1.27	7.08	18.80	0.00	0.00	
20	37,210	1.03	7.04	—	23,210	18,490	1.09	7.07	18.80	0.00	0.00	
21	39,440	1.10	7.02	—	23,230	20,160	0.94	7.09	18.80	0.00	0.00	
22	38,200	1.13	7.02	—	23,380	19,150	1.00	7.05	18.70	0.00	0.00	
23	39,250	1.02	7.05	—	24,210	19,210	0.79	7.08	18.90	0.00	0.00	
24	38,760	1.00	7.03	—	24,220	18,400	0.62	7.04	18.80	0.00	0.00	
25	38,200	1.11	7.01	—	23,820	17,840	0.71	7.00	18.80	0.00	0.00	
26	38,190	1.30	7.02	—	23,610	18,680	0.83	7.00	18.90	0.00	0.00	
27	39,340	1.15	7.03	—	23,800	19,380	0.70	7.01	19.00	0.00	0.00	
28	38,910	1.17	6.97	—	24,200	19,350	0.82	7.03	18.80	0.00	0.00	
29	39,190	1.17	7.02	—	24,020	18,940	1.02	7.03	18.90	0.00	0.00	
30	39,570	1.16	7.01	—	24,660	19,070	0.98	7.03	18.90	0.00	0.00	
31	38,720	1.22	6.98	—	24,570	18,250	0.10	6.97	18.90	0.00	0.00	
合計	1,200,870			—	749,060	566,050				0.00	0.00	
最大	40,350	1.30	7.05	—	26,210	20,930	1.27	7.09	19.00	0.00	0.00	
最小	36,130	0.87	6.94	—	21,970	5,440	0.10	6.97	18.10	0.00	0.00	
平均	38,738	1.04	7.01	—	24,163	18,260	0.85	7.04	18.61	0.00	0.00	

初野浄水場 流量水質報告書

令和7年9月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	39,350	1.18	6.97	—	24,840	18,130	0.97	7.03	19.00	0.00	0.00	
2	38,680	1.08	6.98	—	23,790	18,920	1.09	6.99	19.00	0.00	0.00	
3	39,000	1.14	6.97	—	23,290	18,480	0.96	7.01	18.90	0.00	0.00	
4	40,340	1.09	6.93	—	25,230	21,030	0.99	6.97	18.90	0.00	0.00	
5	37,220	1.15	6.90	—	23,250	18,100	0.94	6.96	18.90	0.00	0.00	
6	38,860	1.11	6.93	—	24,080	18,670	1.03	6.98	19.00	0.00	0.00	
7	37,770	1.05	6.96	—	24,120	17,640	1.10	6.98	18.90	0.00	0.00	
8	39,250	1.01	6.91	—	24,790	18,460	0.86	6.95	18.90	0.00	0.00	
9	38,330	1.02	6.88	—	24,060	18,860	0.84	6.91	18.90	0.00	0.00	
10	38,630	1.07	6.90	—	23,970	18,860	0.83	6.97	18.90	0.00	0.00	
11	39,940	1.03	6.80	—	24,990	19,030	0.75	6.82	16.40	0.00	0.00	
12	38,490	1.10	6.84	—	24,130	18,060	0.75	6.88	16.40	0.00	0.00	
13	39,580	1.03	6.83	—	24,850	18,710	0.75	6.82	16.40	0.00	0.00	
14	38,600	1.02	6.85	—	24,970	17,990	0.76	6.88	16.60	0.00	0.00	
15	38,670	1.01	6.85	—	25,020	17,580	0.70	6.86	16.50	0.00	0.00	
16	38,900	0.98	6.89	—	24,680	18,110	0.92	6.89	16.70	0.00	0.00	
17	38,220	0.92	6.90	—	23,560	18,850	1.02	6.90	16.80	0.00	0.00	
18	39,860	1.05	6.87	—	24,810	19,250	0.68	6.94	16.70	0.00	0.00	
19	39,050	0.88	6.86	—	24,630	18,160	0.67	6.91	16.70	0.00	0.00	
20	39,430	0.92	6.85	—	24,750	18,460	0.64	6.88	16.70	0.00	0.00	
21	38,750	0.95	6.87	—	25,320	17,860	0.60	6.92	16.70	0.00	0.00	
22	39,990	0.93	6.88	—	25,830	17,840	0.63	6.95	16.70	0.00	0.00	
23	38,280	0.99	6.98	—	23,840	17,800	0.70	6.97	16.80	0.00	0.00	
24	39,110	1.01	6.88	—	24,560	18,300	0.69	6.95	16.80	0.00	0.00	
25	38,380	0.98	6.89	—	23,820	18,060	0.68	6.95	16.80	0.00	0.00	
26	38,900	0.87	6.87	—	24,410	18,930	0.65	6.90	16.90	0.00	0.00	
27	38,770	0.89	6.89	—	23,700	18,920	0.67	6.96	16.80	0.00	0.00	
28	37,900	0.90	6.91	—	24,060	17,640	0.71	6.95	16.80	0.00	0.00	
29	38,620	0.98	6.89	—	24,270	18,630	0.73	6.93	17.00	0.00	0.00	
30	36,760	0.90	6.93	—	23,120	17,760	0.70	6.94	16.70	0.00	0.00	
合計	1,163,630			—	730,740	553,090				0.00	0.00	
最大	40,340	1.18	6.98	—	25,830	21,030	1.10	7.03	19.00	0.00	0.00	
最小	36,760	0.87	6.80	—	23,120	17,580	0.60	6.82	16.40	0.00	0.00	
平均	38,788	1.01	6.90	—	24,358	18,436	0.80	6.93	17.44	0.00	0.00	

初野浄水場 流量水質報告書

令和7年10月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	38,580	0.99	6.93	—	23,900	18,650	0.73	6.92	16.70	0.00	0.00	
2	37,570	0.93	6.93	—	23,290	18,350	0.74	6.97	16.80	0.00	0.00	
3	37,530	0.99	6.93	—	23,030	18,100	0.75	6.93	16.70	0.00	0.00	
4	38,250	1.04	6.93	—	23,570	18,320	0.72	6.95	16.80	0.00	0.00	
5	37,940	0.99	6.94	—	23,850	17,740	0.73	6.90	16.80	0.00	0.00	
6	37,740	0.97	6.92	—	23,940	17,770	0.77	6.91	16.80	0.00	0.00	
7	38,080	0.98	6.91	—	23,100	18,520	0.77	6.92	16.60	0.00	0.00	
8	38,250	1.02	6.91	—	23,640	18,340	0.83	6.92	16.70	0.00	0.00	
9	37,920	1.10	6.90	—	23,400	18,270	0.85	6.93	16.70	0.00	0.00	
10	37,950	1.06	6.88	—	23,420	18,270	0.84	6.93	16.60	0.00	0.00	
11	38,170	1.02	6.86	—	23,480	18,540	0.85	6.91	16.40	0.00	0.00	
12	38,150	1.05	6.83	—	24,180	17,710	0.90	6.85	16.40	0.00	0.00	
13	38,300	1.10	6.90	—	24,570	17,620	0.95	6.89	16.50	0.00	0.00	
14	37,140	1.15	6.91	—	23,310	17,460	0.96	6.92	16.40	0.00	0.00	
15	38,270	1.22	6.92	—	23,630	18,590	1.01	6.94	16.40	0.00	0.00	
16	37,190	1.20	6.97	—	22,660	17,860	1.01	6.95	16.30	0.00	0.00	
17	37,980	1.28	6.92	—	23,160	18,420	1.08	6.92	16.40	0.00	0.00	
18	37,840	1.26	6.95	—	22,160	18,270	1.14	6.96	16.30	0.00	0.00	
19	37,910	1.29	6.98	—	23,530	18,200	1.12	6.98	16.40	0.00	0.00	
20	36,870	1.31	6.98	—	23,780	16,960	1.09	6.98	16.20	0.00	0.00	
21	38,580	1.33	6.96	—	23,750	18,220	1.11	6.99	16.10	0.00	0.00	
22	38,430	1.35	6.99	—	23,610	18,400	1.19	7.00	16.00	0.00	0.00	
23	36,990	1.36	6.98	—	22,720	17,380	1.22	7.00	15.80	0.00	0.00	
24	38,410	1.40	6.97	—	23,790	18,420	1.16	6.99	15.70	0.00	0.00	
25	37,430	1.44	6.94	—	22,650	17,950	1.15	6.95	15.70	0.00	0.00	
26	37,960	1.39	6.94	—	24,360	17,280	1.19	6.93	15.70	0.00	0.00	
27	37,120	1.39	6.95	—	24,190	16,910	1.17	6.91	15.70	0.00	0.00	
28	37,880	1.42	6.97	—	23,420	17,700	1.16	6.95	15.60	0.00	0.00	
29	38,210	1.36	6.97	—	24,100	18,060	1.17	6.96	15.40	0.00	0.00	
30	38,210	1.36	7.09	—	23,910	17,650	1.38	7.02	15.20	0.00	0.00	
31	36,990	1.84	7.10	—	22,270	15,720	1.42	6.83	15.10	0.00	0.00	
合計	1,173,840			—	728,370	555,650				0.00	0.00	
最大	38,580	1.84	7.10	0.00	24,570	18,650	1.42	7.02	16.80	0.00	0.00	
最小	36,870	0.93	6.83	0.00	22,160	15,720	0.72	6.83	15.10	0.00	0.00	
平均	37,866	1.21	6.94	—	23,496	17,924	1.01	6.94	16.22	0.00	0.00	

初野浄水場 流量水質報告書

令和7年11月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	34,700	1.83	7.06	—	21,280	16,310	1.41	6.78	15.10	0.00	0.00	
2	37,510	1.93	7.10	—	24,140	17,080	1.49	6.85	15.10	0.00	0.00	
3	37,830	2.01	7.11	—	24,490	17,300	1.54	6.86	15.00	0.00	0.00	
4	38,050	1.99	7.15	—	24,290	17,390	1.51	6.86	14.80	0.00	0.00	
5	38,130	2.05	7.14	—	22,380	17,310	1.59	6.93	14.60	0.00	0.00	
6	37,730	2.08	7.12	—	22,970	17,460	1.60	6.88	14.50	0.00	0.00	
7	37,150	2.10	7.17	—	20,870	17,350	1.64	6.84	14.50	0.00	0.00	
8	38,170	2.10	7.13	—	23,330	17,620	1.59	6.81	14.30	0.00	0.00	
9	37,710	2.15	7.16	—	24,270	16,680	1.61	6.82	14.20	0.00	0.00	
10	37,780	2.13	7.15	—	24,440	16,730	1.63	6.83	14.20	0.00	0.00	
11	37,640	2.17	7.15	—	23,610	17,290	1.63	6.85	14.00	0.00	0.00	
12	37,750	2.22	7.16	—	24,230	16,640	1.67	6.86	13.70	0.00	0.00	
13	38,270	2.26	7.14	—	23,060	17,140	1.79	6.90	13.50	0.00	0.00	
14	37,550	2.26	7.17	—	23,820	16,280	1.77	6.84	13.40	0.00	0.00	
15	38,290	2.20	7.19	—	24,170	17,140	1.72	6.88	13.20	0.00	0.00	
16	37,150	2.15	7.15	—	23,650	16,580	1.73	6.87	13.10	0.00	0.00	
17	37,770	2.19	7.13	—	24,070	16,670	1.77	6.87	13.10	0.00	0.00	
18	36,560	2.19	7.14	—	22,690	17,280	1.75	6.86	13.00	0.00	0.00	
19	37,290	2.16	7.16	—	23,390	17,030	1.70	6.86	12.60	0.00	0.00	
20	37,720	2.18	7.17	—	23,170	17,260	1.67	6.90	12.50	0.00	0.00	
21	36,980	2.21	7.14	—	23,150	16,970	1.72	6.85	12.40	0.00	0.00	
22	37,810	2.11	7.15	—	23,390	17,590	1.69	6.83	12.20	0.00	0.00	
23	37,120	2.12	7.16	—	23,220	16,620	1.66	6.96	12.00	0.00	0.00	
24	37,430	2.15	7.15	—	24,130	16,360	1.68	6.85	12.00	0.00	0.00	
25	36,940	2.02	7.17	—	23,210	16,570	1.65	6.85	12.10	0.00	0.00	
26	38,410	2.00	7.17	—	24,410	17,540	1.61	6.86	11.90	0.00	0.00	
27	37,560	1.90	7.17	—	23,320	17,080	1.55	6.86	11.90	0.00	0.00	
28	37,320	1.88	7.16	—	23,270	17,360	1.49	6.85	11.80	0.00	0.00	
29	36,890	2.04	7.15	—	22,670	17,720	1.53	6.90	11.50	0.00	0.00	
30	36,780	1.96	7.22	—	23,170	16,550	1.53	6.88	11.30	0.00	0.00	
合計	1,123,990			—	702,260	510,900				0.00	0.00	
最大	38,410	2.26	7.22		24,490	17,720	1.79	6.96	15.10	0.00	0.00	
最小	34,700	1.83	7.06		20,870	16,280	1.41	6.78	11.30	0.00	0.00	
平均	37,466	2.09	7.15	—	23,409	17,030	1.63	6.86	13.25	0.00	0.00	

初野浄水場 流量水質報告書

令和7年12月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	36,230	2.05	7.16	—	22,820	16,270	1.59	6.88	11.30	0.00	0.00	
2	37,320	2.05	7.17	—	23,540	17,250	1.64	6.86	11.40	0.00	0.00	
3	37,480	2.07	7.17	—	23,490	17,320	1.67	6.86	11.20	0.00	0.00	
4	36,460	2.19	7.16	—	22,230	16,950	1.62	6.89	10.90	0.00	0.00	
5	37,620	2.11	7.18	—	23,520	17,410	1.61	6.87	10.60	0.00	0.00	
6	37,900	2.14	7.20	—	23,890	18,180	1.61	6.88	10.50	0.00	0.00	
7	37,120	2.46	7.17	—	23,790	17,020	1.83	6.91	10.40	0.00	0.00	
8	37,530	2.38	7.19	—	23,760	17,210	1.83	6.86	10.40	0.00	0.00	
9	37,970	2.38	7.14	—	23,870	18,340	1.81	6.87	10.30	0.00	0.00	
10	37,080	2.46	7.20	—	23,460	17,380	1.89	6.88	10.10	0.00	0.00	
11	36,600	2.54	7.20	—	22,920	17,270	1.98	6.90	10.00	0.00	0.00	
12	37,790	2.61	7.18	—	22,330	18,120	2.15	6.89	9.70	0.00	0.00	
13	37,410	4.23	7.14	—	22,780	18,290	2.72	6.88	9.40	0.00	0.00	
14	37,310	3.17	7.21	—	23,450	17,360	2.58	6.92	9.10	0.00	0.00	
15	36,970	3.04	7.21	—	23,820	17,180	2.47	6.93	9.30	0.00	0.00	
16	36,900	3.12	7.23	—	22,380	17,880	2.79	6.99	9.00	0.00	0.00	
17	37,790	3.50	7.21	—	22,980	18,250	3.06	6.93	8.90	0.00	0.00	
18	36,560	3.61	7.19	—	21,900	17,960	3.09	6.90	8.80	0.00	0.00	
19	37,050	3.22	7.26	—	22,380	17,860	2.75	6.92	8.70	0.00	0.00	
20	36,830	3.38	7.23	—	22,760	17,860	2.87	6.92	8.70	0.00	0.00	
21	37,020	3.47	7.25	—	23,450	17,620	2.89	6.90	9.00	0.00	0.00	
22	36,640	3.29	7.24	—	23,570	17,240	2.82	6.94	9.00	0.00	0.00	
23	37,730	3.77	7.24	—	23,580	18,050	3.00	6.99	8.80	0.00	0.00	
24	36,980	4.60	7.20	—	22,840	17,600	3.72	7.01	8.60	0.00	0.00	
25	38,140	3.88	7.23	—	24,000	18,120	3.57	6.97	8.70	0.00	0.00	
26	36,000	4.12	7.21	—	22,580	17,190	3.76	6.86	8.50	0.00	0.00	
27	37,010	3.86	7.20	—	23,000	17,750	3.44	6.88	8.30	0.00	0.00	
28	37,000	3.63	7.24	—	23,500	16,850	3.20	6.90	8.10	0.00	0.00	
29	37,300	3.51	7.24	—	23,690	16,960	3.07	6.95	8.00	0.00	0.00	
30	37,170	3.91	7.22	—	23,380	16,640	3.15	6.89	8.10	0.00	0.00	
31	37,250	3.78	7.23	—	23,140	16,840	3.24	6.98	8.00	0.00	0.00	
合計	1,152,160			—	718,800	542,220				0.00	0.00	
最大	38,140	4.60	7.26	—	24,000	18,340	3.76	7.01	11.40	0.00	0.00	
最小	36,000	2.05	7.14	—	21,900	16,270	1.59	6.86	8.00	0.00	0.00	
平均	37,166	3.11	7.20	—	23,187	17,491	2.56	6.91	9.41	0.00	0.00	

初野浄水場 流量水質報告書

令和8年1月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	36,910	3.87	7.22	—	23,010	16,050	3.34	6.86	7.90	0.00	0.00	
2	36,840	4.08	7.19	—	23,890	17,060	3.50	6.87	7.70	0.00	0.00	
3	37,460	4.17	7.20	—	24,060	16,750	3.37	6.88	7.60	0.00	0.00	
4	36,750	4.02	7.19	—	23,940	16,490	3.56	6.85	7.50	0.00	0.00	
5	36,910	3.91	7.24	—	23,550	16,860	3.33	6.89	7.50	0.00	0.00	
6	36,560	4.48	7.19	—	23,030	17,660	3.84	6.89	7.30	0.00	0.00	
7	38,800	4.21	7.22	—	24,580	18,710	3.61	6.88	7.10	0.00	0.00	
8	35,410	4.38	7.22	—	21,390	17,110	3.41	6.91	7.10	0.00	0.00	
9	37,360	4.29	7.22	—	23,290	17,790	3.71	6.91	6.90	0.00	0.00	
10	37,160	4.03	7.29	—	23,000	17,740	3.37	6.97	6.80	0.00	0.00	
11	37,060	5.19	7.28	—	23,830	17,710	4.07	6.96	6.90	0.00	0.00	
12	37,200	4.25	7.30	—	24,260	17,480	3.56	6.98	6.70	0.00	0.00	
13	37,220	4.08	7.33	—	23,380	17,580	3.57	6.99	6.60	0.00	0.00	
14	36,990	3.94	7.31	—	23,420	17,980	3.45	6.99	6.60	0.00	0.00	
15	36,950	4.44	7.36	—	23,430	17,820	3.94	7.01	6.50	0.00	0.00	
16	37,030	4.55	7.35	—	23,480	17,380	4.21	7.06	6.50	0.00	0.00	
17	36,630	4.03	7.38	—	22,570	18,390	3.46	7.04	6.50	0.00	0.00	
18	37,070	4.29	7.37	—	23,800	17,700	3.48	7.04	6.30	0.00	0.00	
19	36,790	4.43	7.41	—	23,800	17,290	3.89	7.04	6.20	0.00	0.00	
20	37,030	5.41	7.37	—	23,290	17,790	4.75	7.05	6.00	0.00	0.00	
21	36,770	5.22	7.42	—	22,940	17,580	4.57	7.07	5.80	0.00	0.00	
22	36,800	4.59	7.46	—	22,690	17,700	4.06	7.08	5.60	0.00	0.00	
23	37,350	4.29	7.47	—	23,070	17,870	3.82	7.09	5.60	0.00	0.00	
24	37,140	4.07	7.47	—	23,310	17,910	3.58	7.10	5.60	0.00	0.00	
25	36,290	4.09	7.45	—	22,530	17,030	3.51	7.10	5.40	0.00	0.00	
26	36,960	4.15	7.43	—	23,510	17,440	3.66	7.07	5.20	0.00	0.00	
27	36,680	4.05	7.50	—	22,770	17,720	3.54	7.10	5.30	0.00	0.00	
28	36,320	3.74	7.46	—	21,840	17,660	3.33	7.11	5.20	0.00	0.00	
29	37,100	3.76	7.49	—	22,800	17,880	3.50	7.09	5.10	0.00	0.00	
30	36,550	3.62	7.50	—	22,370	17,620	3.07	7.12	5.00	0.00	0.00	
31	36,270	3.57	7.51	—	22,260	17,550	3.11	7.11	4.90	0.00	0.00	
合計	1,144,360			—	719,090	543,300				0.00	0.00	
最大	38,800	5.41	7.51	—	24,580	18,710	4.75	7.12	7.90	0.00	0.00	
最小	35,410	3.57	7.19	—	21,390	16,050	3.07	6.85	4.90	0.00	0.00	
平均	36,915	4.23	7.35	—	23,196	17,526	3.65	7.00	6.35	0.00	0.00	

初野浄水場 流量水質報告書

令和8年2月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	36,630	3.48	7.51	—	22,690	17,460	3.06	7.11	4.90	0.00	0.00	
2	36,500	3.25	7.52	—	22,960	17,300	2.76	7.13	4.90	0.00	0.00	
3	36,450	3.31	7.51	—	22,310	17,480	3.16	7.13	4.90	0.00	0.00	
4	36,930	3.34	7.54	—	22,660	17,700	3.11	7.12	4.90	0.00	0.00	
5	37,660	3.14	7.52	—	23,070	18,270	2.84	7.13	5.00	0.00	0.00	
6	37,700	3.18	7.51	—	22,850	18,420	2.89	7.12	5.00	0.00	0.00	
7	35,950	2.80	7.52	—	21,740	17,470	2.54	7.12	4.90	0.00	0.00	
8	37,040	3.14	7.56	—	23,700	17,350	2.93	7.12	4.70	0.00	0.00	
9	38,610	3.02	7.54	—	25,530	17,080	2.70	7.13	4.50	0.00	0.00	
10	38,220	3.07	7.54	—	24,320	17,530	2.75	7.15	4.50	0.00	0.00	
11	38,970	2.99	7.53	—	24,730	18,380	2.62	7.13	4.60	0.00	0.00	
12	38,100	2.82	7.53	—	24,780	17,970	2.55	7.15	4.50	0.00	0.00	
13	38,440	2.73	7.55	—	24,440	17,960	2.37	7.14	4.50	0.00	0.00	
14	38,170	2.56	7.57	—	24,650	17,800	2.32	7.16	4.60	0.00	0.00	
15	37,180	2.44	7.57	—	23,950	17,340	2.06	7.16	4.60	0.00	0.00	
16	37,000	2.27	7.56	—	23,580	16,920	1.87	7.16	4.90	0.00	0.00	
17	37,890	2.23	7.57	—	24,040	17,900	1.86	7.15	5.00	0.00	0.00	
18	37,310	2.57	7.54	—	24,010	17,550	2.14	7.16	4.90	0.00	0.00	
19	37,900	2.43	7.54	—	24,000	17,940	1.91	7.16	4.80	0.00	0.00	
20	38,020	2.94	7.54	—	24,890	17,920	2.60	7.12	4.80	0.00	0.00	
21	38,100	2.64	7.61	—	24,430	17,850	2.29	7.16	4.80	0.00	0.00	
22	37,410	2.56	7.56	—	24,760	17,320	2.22	7.16	4.80	0.00	0.00	
23	38,170	2.50	7.57	—	25,520	15,230	2.17	7.14	5.00	0.00	0.00	
24	39,150	2.37	7.54	—	25,760	14,870	1.91	7.16	5.30	0.00	0.00	
25	38,970	2.67	7.50	—	25,480	14,890	2.58	7.16	5.20	0.00	0.00	
26	36,510	2.71	7.49	—	24,130	19,800	2.49	7.10	5.10	0.00	0.00	
27	38,130	2.37	7.53	—	24,840	17,410	1.99	7.13	5.20	0.00	0.00	
28	37,980	2.42	7.52	—	25,040	17,420	2.06	7.14	5.40	0.00	0.00	
合計	1,055,090			—	674,860	488,530				0.00	0.00	
最大	39,150	3.48	7.61	—	25,760	19,800	3.16	7.16	5.40	0.00	0.00	
最小	35,950	2.23	7.49	—	21,740	14,870	1.86	7.10	4.50	0.00	0.00	
平均	37,682	2.78	7.54	—	24,102	17,448	2.46	7.14	4.86	0.00	0.00	

初野浄水場 流量水質報告書

令和8年3月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	38,260	2.25	7.61	—	25,320	17,250	1.73	7.17	5.60	0.00	0.00	
2	38,390	2.38	7.60	—	25,290	17,340	1.74	7.19	5.70	0.00	0.00	
3	37,510	2.63	7.57	—	23,690	17,430	2.15	7.12	5.70	0.00	0.00	
4	38,320	2.89	7.51	—	25,000	17,460	2.36	7.11	5.30	0.00	0.00	
5	37,830	2.51	7.54	—	24,940	17,480	1.98	7.15	5.50	0.00	0.00	
6	38,230	2.92	7.55	—	24,660	17,730	2.38	7.16	5.60	0.00	0.00	
7	38,010	2.72	7.55	—	24,570	17,710	2.23	7.13	5.70	0.00	0.00	
8	37,890	2.79	7.54	—	25,190	17,140	2.19	7.12	5.70	0.00	0.00	
9	38,220	2.93	7.54	—	25,420	17,060	2.39	7.16	5.70	0.00	0.00	
10	37,430	2.81	7.56	—	24,350	17,310	2.29	7.17	5.80	0.00	0.00	
11	37,790	2.80	7.52	—	25,130	17,370	2.11	7.14	5.80	0.00	0.00	
12	38,180	2.68	7.56	—	24,920	17,510	2.22	7.17	6.10	0.00	0.00	
13	38,830	2.68	7.58	—	24,100	18,230	2.05	7.19	6.10	0.00	0.00	
14	37,430	2.53	7.58	—	24,370	17,370	2.02	7.15	6.10	0.00	0.00	
15	37,840	2.60	7.57	—	25,230	16,870	1.98	7.17	6.30	0.00	0.00	
16	37,980	2.43	7.56	—	25,020	16,900	1.96	7.15	6.40	0.00	0.00	
17	38,090	2.48	7.57	—	24,590	17,940	1.91	7.19	6.60	0.00	0.00	
18	37,640	2.37	7.59	—	24,640	17,390	1.88	7.14	6.30	0.00	0.00	
19	37,980	2.40	7.53	—	24,520	17,690	1.92	7.11	6.40	0.00	0.00	
20	38,050	2.35	7.63	—	24,860	17,800	1.87	7.19	7.00	0.00	0.00	
21	37,910	2.26	7.61	—	24,710	17,270	1.89	7.16	6.70	0.00	0.00	
22	37,820	2.42	7.65	—	25,160	16,790	1.90	7.20	7.00	0.00	0.00	
23	38,100	2.82	7.58	—	24,990	17,220	2.30	7.13	6.90	0.00	0.00	
24	38,350	2.50	7.60	—	25,140	17,980	1.92	7.17	7.10	0.00	0.00	
25	37,360	2.54	7.57	—	24,350	17,240	2.01	7.15	7.10	0.00	0.00	
26	38,660	2.47	7.53	—	25,220	17,580	2.01	7.12	7.00	0.00	0.00	
27	37,650	2.49	7.51	—	24,960	17,100	1.92	7.12	7.00	0.00	0.00	
28	38,490	2.42	7.56	—	25,300	17,180	1.87	7.14	7.10	0.00	0.00	
29	37,890	2.32	7.55	—	25,100	18,630	1.82	7.11	7.20	0.00	0.00	
30	38,360	2.23	7.58	—	25,630	16,890	1.74	7.10	7.20	0.00	0.00	
31	37,160	2.17	7.57	—	24,750	13,410	1.74	7.09	7.30	0.00	0.00	
合計	1,177,650			—	771,120	536,270				0.00	0.00	
最大	38,830	2.93	7.65	—	25,630	18,630	2.39	7.20	7.30	0.00	0.00	
最小	37,160	2.17	7.51	—	23,690	13,410	1.73	7.09	5.30	0.00	0.00	
平均	37,989	2.54	7.57	—	24,875	17,299	2.02	7.15	6.35	0.00	0.00	