

初野浄水場 流量水質報告書

令和8年6月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (℃)	P A C	苛性 ソーダ	
1	37,990	3.61	6.85	—	24,760	12,920	3.01	6.90	15.10	0.00	0.00	
2	36,900	3.20	6.83	—	23,050	17,060	2.53	6.84	14.50	0.00	0.00	
3	38,590	3.13	6.80	—	24,630	11,770	2.49	6.79	14.40	0.00	0.00	
4	37,410	3.62	6.79	—	24,420	12,290	3.02	6.80	14.40	0.00	0.00	
5	36,890	3.68	6.76	—	24,010	12,140	2.94	6.83	14.30	0.00	0.00	
6	37,800	4.49	6.69	—	24,590	14,750	3.20	6.75	14.30	0.00	0.00	
7	37,370	5.04	6.74	—	24,650	13,400	4.33	6.73	14.40	0.00	0.00	
8	39,790	5.40	6.67	—	26,410	14,240	4.48	6.69	14.60	0.00	0.00	
9	36,520	5.05	6.72	—	23,290	12,820	4.55	6.74	14.80	0.00	0.00	
10	38,310	4.80	6.78	—	24,420	13,980	4.06	6.82	15.20	0.00	0.00	
11	38,210	4.59	6.83	—	23,350	15,840	3.82	6.83	15.10	0.00	0.00	
12	37,500	4.59	6.85	—	22,860	19,820	3.71	6.83	15.10	0.00	0.00	
13	38,590	4.63	6.81	—	24,820	20,560	3.84	6.82	15.10	0.00	0.00	
14	38,060	4.33	6.75	—	24,700	19,550	3.36	6.79	15.30	0.00	0.00	
15	38,110	4.29	6.77	—	24,850	19,410	3.55	6.84	15.20	0.00	0.00	
16	37,440	4.38	6.82	—	24,100	20,100	3.36	6.85	15.30	0.00	0.00	
17	37,860	4.01	6.81	—	23,230	20,730	3.16	6.88	15.40	0.00	0.00	
18	38,040	3.82	6.80	—	23,730	21,000	2.99	6.85	15.40	0.00	0.00	
19	38,840	3.65	6.81	—	24,540	21,110	2.85	6.90	15.60	0.00	0.00	
20	37,370	3.54	6.81	—	23,590	20,020	2.86	6.88	15.40	0.00	0.00	
21	37,560	3.52	6.79	—	24,560	19,550	2.83	6.91	15.50	0.00	0.00	
22	38,060	3.64	6.77	—	25,080	19,400	2.85	6.84	15.60	0.00	0.00	
23	37,840	3.49	6.81	—	24,660	19,630	2.83	6.82	15.50	0.00	0.00	
24	37,010	3.39	6.84	—	23,650	19,670	2.73	6.80	15.50	0.00	0.00	
25	38,030	3.31	6.86	—	23,740	21,010	2.79	6.80	15.60	0.00	0.00	
26	38,000	3.18	6.75	—	23,760	20,980	2.53	6.74	15.60	0.00	0.00	
27	37,550	3.39	6.75	—	24,220	20,940	2.53	6.79	15.90	0.00	0.00	
28	38,220	3.22	6.80	—	24,710	20,240	2.37	6.75	15.90	0.00	0.00	
29	37,870	3.05	6.78	—	24,000	20,090	2.29	6.81	16.00	0.00	0.00	
30	38,410	2.86	6.72	—	24,190	21,490	2.18	6.75	16.00	0.00	0.00	
合計	1,136,140			—	726,570	536,510				0.00	0.00	
最大	39,790	5.40	6.86	—	26,410	21,490	4.55	6.91	16.00	0.00	0.00	
最小	36,520	2.86	6.67	—	22,860	11,770	2.18	6.69	14.30	0.00	0.00	
平均	37,871	3.90	6.79	—	24,219	17,884	3.13	6.81	15.20	0.00	0.00	